

**CHAPTER 7151**  
**MINNESOTA POLLUTION CONTROL AGENCY**  
**ABOVEGROUND STORAGE OF LIQUID SUBSTANCES**

GENERAL	OPERATION AND MAINTENANCE OF ABOVEGROUND STORAGE TANKS
7151.1100 PURPOSE.	7151.7100 REQUIREMENT.
7151.1200 DEFINITIONS.	7151.7200 MONITORING.
7151.1300 APPLICABILITY.	7151.7300 MAINTENANCE.
7151.2100 INCORPORATIONS BY REFERENCE.	7151.7400 RECORDS.
7151.3100 TANK SERVICE PROVIDERS.	7151.7500 RELEASES AND DISCHARGES TO A SECONDARY CONTAINMENT AREA.
7151.4100 TEMPORARY STORAGE.	
<b>STANDARDS FOR NEW ABOVEGROUND STORAGE TANKS</b>	<b>WITHDRAWAL FROM SERVICE OF ABOVEGROUND STORAGE TANK SYSTEMS</b>
7151.5100 REQUIREMENT.	7151.8100 REQUIREMENT.
7151.5200 TANK AND PIPING STANDARDS.	7151.8200 OUT-OF-SERVICE ABOVEGROUND STORAGE TANK SYSTEMS.
7151.5300 LABELING.	7151.8300 REACTIVATING OUT-OF-SERVICE ABOVEGROUND STORAGE TANK SYSTEMS.
7151.5400 SECONDARY CONTAINMENT.	7151.8400 CONTAMINATION DETERMINATION.
7151.5500 SUBSTANCE TRANSFER AREAS.	7151.8500 CONTAMINATION DETERMINATION FOR PREVIOUSLY CLOSED ABOVEGROUND STORAGE TANK SYSTEMS.
7151.5600 CORROSION PROTECTION.	
7151.5700 OVERFILL PROTECTION.	<b>MISCELLANEOUS</b>
<b>STANDARDS FOR EXISTING ABOVEGROUND STORAGE TANKS</b>	7151.9100 INADEQUATE SAFEGUARDS.
7151.6100 REQUIREMENT.	7151.9200 PROCEDURAL RULES AND APPEALS.
7151.6200 TANK AND PIPING STANDARDS.	7151.9300 VARIANCES.
7151.6300 LABELING.	7151.9400 ALTERNATIVE DESIGN OR OPERATING PRACTICE.
7151.6400 SECONDARY CONTAINMENT.	7151.9500 RELEASE REPORTING.
7151.6500 SUBSTANCE TRANSFER AREAS.	7151.9600 OTHER REGULATIONS.
7151.6600 CORROSION PROTECTION.	
7151.6700 OVERFILL PROTECTION.	

**GENERAL**

**7151.1100 PURPOSE.**

The purpose of this chapter is to provide for the protection of the public health and the environment by establishing uniform performance standards and technical requirements for aboveground storage of liquid substances which may cause pollution of waters of the state.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883; 25 SR 556*

**7151.1200 DEFINITIONS.**

Subpart 1. **Scope.** For the purposes of this chapter, the following terms have the meanings given them. Terms that are not specifically defined have the meanings given them in Minnesota Statutes, section 115.01, 115C.02, or 116.46.

Subp. 2. **Aboveground storage tank system or tank system.** "Aboveground storage tank system" or "tank system" means any one or a combination of containers, vessels, and enclosures, including structures and appurtenances connected to them, that is used to contain or dispense substances, and that is not an underground storage tank under Minnesota Statutes, section 116.46, subdivision 8.

Subp. 3. **Agency.** "Agency" means the Minnesota Pollution Control Agency.

Subp. 4. **Appurtenances.** "Appurtenances" means any aboveground or underground lines connected to an aboveground storage tank that are two inches or greater inside diameter, together with any associated valves and manifolds, to the point where the piping is located indoors.

Subp. 4a. **Asphalt cement.** "Asphalt cement" means a mixture of bituminous obtained from native deposits or as a petroleum by-product used for roofing or paving that is in a solid state at 100 degrees Fahrenheit or less.

Subp. 5. **Capacity.** "Capacity" means the maximum volume of a substance in gallons that may be contained by an aboveground storage tank pursuant to the tank's design.

# MINNESOTA RULES 2007

1531

## ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.1200

Subp. 6. **Cathodic protection.** “Cathodic protection” means the technique to prevent corrosion of a metal surface by making that surface the cathode of an electrochemical cell through the application of either galvanic anodes or impressed current.

Subp. 7. **Cathodic protection tester.** “Cathodic protection tester” means a person who demonstrates an understanding of the principles and measurements of cathodic protection systems as applied to metal piping and tanks. At a minimum, such persons shall have education and experience in soil resistivity, stray current, structure-to-soil potential, and component electrical isolation measurements of metal piping and tanks.

Subp. 8. **Class 2 surface water.** “Class 2 surface water,” as defined in part 7050.0200, means all waters of the state that are or may be used for fishing, fish culture, bathing, or any other recreational purpose, and for which quality control is or may be necessary to protect aquatic or terrestrial life, or the public health, safety, or welfare.

Subp. 9. **Compatible.** “Compatible” means the ability of two or more substances or materials in a tank system to maintain their respective physical and chemical properties upon contact with one another.

Subp. 10. **Corrosion expert.** “Corrosion expert” means a person who, by reason of thorough knowledge of the physical sciences and the principles of engineering and mathematics acquired by a professional education and related practical experience, is qualified to engage in the application of corrosion control on metal piping systems and metal tanks. The person shall be accredited, certified by the National Association of Corrosion Engineers, or a registered professional engineer who has certification or licensing that includes education and experience in corrosion control of metal piping systems and metal tanks.

Subp. 11. **Dike.** “Dike” means an embankment, ridge, or wall which is impermeable to stored substances and which forms the perimeter of the secondary containment area.

Subp. 12. **Discharge into a secondary containment area.** “Discharge into a secondary containment area” means a spill, leak, or discharge of a substance from a tank or its appurtenances into a structure specifically designed and constructed to prevent a spill, leak, or discharge from spreading vertically or horizontally and contaminating the land or water outside the containment area.

Subp. 12a. **Double-bottomed tank.** “Double-bottomed tank” means a field-erected aboveground storage tank that has been designed or modified to include a second tank bottom and where (A) the bottoms are compatible with and impermeable to the substance being stored, (B) the interstitial space between the bottoms is filled with a minimum of three inches of a neutral sand or other noncorrosive material cushion, and (C) there is a method in place for monitoring the interstitial space for leaks.

Subp. 13. **Double-walled tank.** “Double-walled tank” means an aboveground storage tank with an inner, primary shell and an outer, secondary shell that extends around the entire inner shell, and a method in place for monitoring the interstitial space between the shells for leaks.

Subp. 14. **Electrical equipment.** “Electrical equipment” means equipment such as transformers which contain dielectric fluid necessary for operation.

Subp. 14a. **Facility.** “Facility” means an assemblage of one or more aboveground storage tanks, including any indoor tanks, together with any associated secondary containment areas, appurtenances, and substance transfer areas, that are located at a single property or multiple contiguous properties.

Subp. 15. **Farm.** “Farm” means a tract of land devoted to the production of crops or raising of animals.

Subp. 16. **Field-erected tank.** “Field-erected tank” means an aboveground storage tank that is constructed by final assembly on site at a facility.

Subp. 17. **Hazardous material.** “Hazardous material” means any substance listed as a hazardous material or hazardous substance in Code of Federal Regulations, title 49, section 172.101.

Subp. 18. **Heating and cooling equipment.** "Heating and cooling equipment" means equipment intended or installed for the purpose of heating, cooling, and/or conditioning air, water, and/or fluid by mechanical means for environmental, process, or other purposes.

Subp. 19. **Hydraulic lift tank.** "Hydraulic lift tank" means an aboveground storage tank holding hydraulic fluid for a closed-loop mechanical system that uses compressed air or hydraulic fluid to operate lifts, elevators, and other similar devices.

Subp. 20. **Impermeable.** "Impermeable" means the ability to prevent a substance or combination of compatible substances from penetrating through a secondary containment area for a minimum of 72 hours.

Subp. 21. **Indoor tank.** "Indoor tank" means an aboveground storage tank located inside a building or other type of enclosed structure, resting on or elevated above an impermeable floor surface, from which a release would:

- A. be entirely contained within a secondary containment structure;
- B. not escape from the building through any doorways, floor drains, or other means; or
- C. be directed by any drainage system of the building either to a permitted on-site wastewater treatment facility or to a permitted municipal wastewater treatment facility.

Subp. 22. **Major facility.** "Major facility" means an assemblage of one or more aboveground storage tanks, including any indoor tanks, together with any associated secondary containment areas, appurtenances, and substance transfer areas, that are located at a single property or multiple contiguous properties and where the total substance design storage capacity of all such tanks at the site is 1,000,000 gallons or greater.

Subp. 23. **Major facility permit.** "Major facility permit" means a permit issued by the agency to a major facility under part 7001.4200. Any tank meeting the definition of indoor tank is excluded from regulation under the terms and conditions of a major facility permit.

Subp. 24. **Operator.** "Operator" means a person in control of or having responsibility for the daily operation of an aboveground storage tank or tank system, or a person who was in control of or had responsibility for the daily operation of a tank or tank system immediately before discontinuation of its use.

Operator also means a person who is responsible under Minnesota Statutes, section 115C.021, for a release from an aboveground storage tank containing petroleum or a person who is responsible under Minnesota Statutes, section 115B.03, for a release from an aboveground storage tank containing a hazardous material.

Subp. 25. **Other regulated substances.** "Other regulated substances" means any substance, including a food-based product intended for human or animal consumption, which may cause pollution of waters of the state and is not:

- A. a petroleum substance under standard temperature and pressure; or
- B. a hazardous material.

Subp. 26. **Owner.** "Owner" means a person who holds title to, controls, or owns an interest in an aboveground storage tank or tank system, or a person who held title to, controlled, or possessed an interest in the tank or tank system immediately before discontinuation of its use.

Owner also means a person who is responsible under Minnesota Statutes, section 115C.021, for a release from an aboveground storage tank containing petroleum or a person who is responsible under Minnesota Statutes, section 115B.03, for a release from an aboveground storage tank containing a hazardous material.

Owner does not include a person who holds an interest in a tank solely for financial security, unless through foreclosure or other related actions the holder of a security interest has taken possession of and operated the tank.

Subp. 27. **Person.** "Person" means an individual, partnership, association, corporation, or other legal entity, including the United States government, an interstate commission or other body, the state, or any agency, board, bureau, office, department, or political subdivision of the state, but does not include the Minnesota Pollution Control Agency.

# MINNESOTA RULES 2007

1533

ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.1200

Subp. 28. **Piping or lines.** “Piping” or “lines” means a hollow cylinder or tubular conduit that is constructed for conveying a substance from one point to another within an aboveground storage tank system.

Subp. 29. **Release.** “Release” means a spill, leak, or discharge of a substance from a tank or its appurtenances to the environment, including a spill, leak, or discharge into the ground underneath a tank or into a substance transfer area. For purposes of this chapter, release does not include intentional venting or fugitive air emissions from a tank allowed under agency rules.

Subp. 30. **Safeguard.** “Safeguard” means a device, system, or combination of devices or systems designed to detect or prevent the escape or movement of a substance from the place of storage under such conditions that might cause pollution of the waters of the state.

Subp. 31. **Secondary containment.** “Secondary containment” means a safeguard specifically designed to be impermeable to stored substances and which will contain a release from an aboveground storage tank or tank system and prevent the release from spreading vertically or horizontally and contaminating the land or water outside the containment area.

Subp. 32. **Shop-fabricated tank.** “Shop-fabricated tank” means an aboveground storage tank that is constructed at a tank manufacturer’s plant and transported to a facility for installation.

Subp. 33. **Substance.** “Substance” means any material which is liquid at ambient pressures and temperatures which may cause pollution of waters of the state.

Subp. 34. **Substance transfer area.** “Substance transfer area” means the area where a truck or rail car makes its connection to or from an aboveground storage tank system for the purpose of unloading or receiving a substance.

Subp. 35. **Tank or aboveground storage tank.** “Tank” or “aboveground storage tank” means a container, vessel, or enclosure designed to contain substances and is constructed of materials such as concrete, steel, plastic, or fiberglass reinforced plastic, provides structural support, and is located aboveground. A tank includes bladders, rail cars, and trucks.

Subp. 36. **Tote tank.** “Tote tank” means an aboveground storage tank that:

- A. is not filled or refilled at the site of substance use;
- B. is 1,100 gallons or less in capacity; and
- C. is located at the site of use for less than 180 days.

Subp. 37. **Type A substances.** “Type A substances” means gasoline, aviation gas, naphtha, denatured ethanol, and hazardous materials, or mixtures or blends containing such substances.

Subp. 38. **Type B substances.** “Type B substances” means crude oil, diesel, kerosene, jet fuel, fuel oil numbers 1 to 4, waste oils, or mixtures or blends of such substances with Type C substances.

Subp. 39. **Type C substances.** “Type C substances” means asphalt cement, roofing flux, fuel oil numbers 5 and 6, and other regulated substances.

Subp. 40. **Underground storage tank.** “Underground storage tank” means any one or combination of containers including tanks, vessels, enclosures, or structures and appurtenances connected to them that is used to contain or dispense regulated substances pursuant to chapter 7150, and the volume of which, including the volume of piping connected to them, is ten percent or more beneath the surface of the ground.

Subp. 41. **Underground piping or underground lines.** “Underground piping” or “underground lines” means a hollow cylinder or tubular conduit, that is two inches or greater inside diameter, that is constructed for conveying a substance from one point to another within an aboveground storage tank system. The volume of piping must be ten percent or more beneath the surface of the ground.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883; 25 SR 556*

**7151.1300 APPLICABILITY.**

Subpart 1. **Scope.** This chapter applies to owners or operators of aboveground storage tank systems except for:

- A. major facilities required to obtain a permit under chapter 7001; and
- B. aboveground storage tank systems exempt under subpart 2.

Subp. 2. **Exclusions.** The following aboveground storage tank systems are excluded from the requirements of this chapter:

A. wastewater treatment equipment including a wastewater clarifier, wastewater treatment basin, and tanks which are regulated under the National Pollutant Discharge Elimination System, the Sewage Disposal System, or other pretreatment permits;

B. equipment or machinery containing substances for operational purposes such as integral hydraulic lift tanks, lubricating oil reservoirs for pumps and motors, electrical equipment, and heating and cooling equipment;

C. an indoor tank;

D. a tote tank;

E. an aboveground storage tank containing hazardous wastes which are subject to a treatment or storage permit issued pursuant to chapter 7001;

F. an aboveground storage tank containing agricultural chemicals regulated under Minnesota Statutes, chapter 18B, 18C, or 18D;

G. a vehicle, such as a tank truck or railroad tank car, designed and used to transport substances from one location to another unless:

(1) the vehicle contains substances and remains in the same location more than 30 consecutive days; or

(2) the vehicle dispenses substances and is refilled while in the same location;

H. a surface impoundment, pit, pond, or lagoon;

I. an aboveground storage tank constructed of stainless steel containing other regulated substances;

J. an aboveground storage tank containing drinking water, filtered surface water, demineralized water, noncontact cooling water, or water stored for fire or emergency purposes and other waters which meet the standards defined in chapter 7050 or 7052;

K. an aboveground storage tank, located on a farm, in which the contents of the tank are used by the tank owner or operator for farming purposes, and the contents are not being commercially distributed;

L. an aboveground storage tank located on residential property of 1,100 gallons or less capacity used for storing motor fuel for noncommercial purposes;

M. an aboveground storage tank of 1,100 gallons or less capacity used for storing heating oil for consumption on the premises where stored;

N. any aboveground storage tank of 1,100 gallons or less capacity, not otherwise exempt under items A to M, unless that tank is greater than 500 gallons capacity and is located within 500 feet of a Class 2 surface water;

O. storm water collection systems;

P. septic tanks; and

Q. an aboveground storage tank that is located at a site for a period of 30 days or less.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883; 25 SR 556*

**7151.2100 INCORPORATIONS BY REFERENCE.**

Subpart 1. **Scope.** For purposes of this chapter, the documents in subpart 2 are incorporated by reference. The documents are not subject to frequent change. They are available at:

A. the addresses shown in subpart 2; and

B. the agency library through the Minitex interlibrary loan system.

# MINNESOTA RULES 2007

1535 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.2100

Subp. 2. **Referenced standards.** The documents incorporated by reference in this chapter are listed in this subpart.

A. American Petroleum Institute (API), 1220 L Street Northwest, Washington, DC 20005:

(1) 570, Piping Inspection Code: Inspection, Repair, Alteration, and Rerating of In-Service Piping Systems (1997);

(2) 620, Design and Construction of Large, Welded, Low-Pressure Storage Tanks, Ninth Edition (1996);

(3) 650, Welded Steel Tanks for Oil Storage, Ninth Edition (1993);

(4) 651, Cathodic Protection of Aboveground Petroleum Storage Tanks, First Edition (1991);

(5) 652, Lining of Aboveground Petroleum Storage Tank Bottoms, First Edition (1991);

(6) 653, Tank Inspection, Repair, Alteration, and Reconstruction, Second Edition (1995);

(7) 1631, Recommended Practice for the Interior Lining of Existing Steel Underground Storage Tanks, Third Edition (1992);

(8) 1632, Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems, Third Edition (1996); and

(9) 2015, Safe Entry and Cleaning of Petroleum Storage Tanks, Planning and Managing Tank Entry from Decommissioning Through Recommissioning, Fifth Edition (1994).

B. American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, West Conshohocken, Pennsylvania 19429-2959:

(1) D1785-96, Specifications for Poly (Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120 (1997); and

(2) *Applicable Standard Practices and Test Methods for Evaluating Soil Permeability Analysis and Sampling.*

C. Code of Federal Regulations, Government Printing Office, P.O. Box 371954, Pittsburgh, PA 15250-7954: title 49, part 172.101, Transportation (1997).

D. National Association of Corrosion Engineers (NACE), Publication Department, P.O. Box 218340, Houston, Texas 77218:

(1) RP-01-69, Control of External Corrosion on Underground or Submerged Metallic Piping Systems (1996); and

(2) RP-02-85, Corrosion Control of Underground Storage Tank Systems by Cathodic Protection (1995).

E. National Leak Prevention Association (NLPA), 7685 Fields Ertel Road, Cincinnati, OH 45241: 631, Spill Prevention, Minimum 10-year Life Extension of Existing Steel Underground Storage Tanks by Lining Without the Addition of Cathodic Protection, Second Edition and Appendices (1991).

F. Steel Tank Institute, 570 Oakwood Road, Lake Zurich, IL 60047:

(1) #F941-97, Standard for Fireguard® Thermally Insulated Aboveground Storage Tanks (1997);

(2) R942-97, Lightweight Double-Wall Steel Aboveground Storage Tanks (1997);

(3) #F921-97, Standard for Aboveground Tanks with Integral Secondary Containment (1997);

(4) #F911-93, Standard for Diked Aboveground Steel Tanks (1993);

(5) R931-93, Double Wall AST Installation and Testing Instructions (1993);

(6) R892-91, Recommended Practice for Corrosion Protection of Underground Piping Networks Associated with Liquid Storage and Dispensing Systems (1991); and

(7) R893-89, Recommended Practice for External Corrosion Protection of Shop Fabricated Aboveground Tank Floors (1989).

# MINNESOTA RULES 2007

## 7151.2100 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES

1536

G. Underwriters Laboratory, Inc. (UL), 333 Pfingsten Road, Northbrook, Illinois 60062:

(1) 109, Tube Fittings for Flammable and Combustible Fluids, Refrigeration Service and Marine Use (1993);

(2) 142, Steel Aboveground Tanks for Flammable and Combustible Liquids (1993);

(3) 567, Pipe Connectors for Petroleum Products and LP-Gas (1996);

(4) 971, Nonmetallic Underground Pipe for Flammable Liquids (1995); and

(5) 2085, Protected Aboveground Tanks for Flammable and Combustible Liquids (1994).

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## 7151.3100 TANK SERVICE PROVIDERS.

Owners and operators shall ensure that tank service providers utilize methods in accordance with guidance specified in applicable industry standards. After the effective date of aboveground storage tank contractor rules adopted pursuant to Minnesota Statutes, section 116.491, owners and operators shall ensure that tank service providers are certified.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## 7151.4100 TEMPORARY STORAGE.

Subpart 1. **Scope.** This part applies to storage of a substance in an aboveground storage tank that is located at a site for a period of more than 30 days but less than one year. Temporary storage tanks regulated under this part are exempt from all other requirements except as provided in subparts 2, 3, and 4.

Subp. 2. **Labeling.** The exterior of a temporary storage tank shall be clearly labeled with the words "Temporary Storage" and the date storage began at the site.

Subp. 3. **Sign.** Tank owners and operators shall provide for a sign at the site of temporary storage tanks pursuant to part 7151.5300, subpart 3.

Subp. 4. **Containment.** Parts 7151.6400 and 7151.7300 apply to the construction and maintenance of secondary containment areas.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## STANDARDS FOR NEW ABOVEGROUND STORAGE TANKS

### 7151.5100 REQUIREMENT.

Subpart 1. **Application and definition.** Except as otherwise provided in subparts 2 and 3, parts 7151.5100 to 7151.5700 apply to the design and installation of all aboveground storage tanks or tank systems installed on or after November 2, 1998.

Subp. 2. **Small tanks near surface water.** Owners and operators of new tanks 1,100 gallons or less but greater than 500 gallons, located within 500 feet of a Class 2 surface water, need not comply with parts 7151.5500, 7151.5600, and 7151.5700.

Subp. 3. **Tanks storing other regulated substances.** Owners and operators of new tanks storing other regulated substances need not comply with parts 7151.5400, subpart 4; 7151.5500; 7151.5600; and 7151.5700.

Subp. 4. **Tanks storing asphalt cement.** Owners and operators of new tanks storing asphalt cement need not comply with parts 7151.5200, subpart 3, item A, subitem (2); 7151.5400, subpart 4; 7151.5500; 7151.5600; and 7151.5700.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

# MINNESOTA RULES 2007

1537 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.5300

## 7151.5200 TANK AND PIPING STANDARDS.

Subpart 1. **Tank and piping design standards.** New tanks and the related appurtenances must be designed and constructed in accordance with the applicable standards under part 7151.2100, subpart 2.

Subp. 2. **Underground storage tanks.** Tanks designed and constructed for service as underground storage tanks must not be used for aboveground storage.

### Subp. 3. **Used aboveground storage tanks.**

A. Except as provided in item C, an aboveground storage tank that has been removed from a facility must not be reinstalled at a second facility for the purpose of substance storage unless:

(1) the tank is determined to be sound by one of the following leak test methods:

- (a) tracer gas test;
- (b) vacuum test;
- (c) air pressure test; or
- (d) hydrostatic test; and

(2) the area of secondary containment at the new location which is directly under the tank is designed and constructed to provide for the detection of a release of a stored substance before the release permeates through the containment. Methods of leak detection include:

(a) visual monitoring of elevated tanks as specified in part 7151.7200, subpart 4;

(b) interstitial monitoring between the tank's inner and outer shell or the tank's shell and the containment area; or

(c) vapor monitoring in the soil directly under the tank bottom or perimeter and above the water table.

B. Except as provided in item C, a tank that has been lifted or moved within a facility must not be reinstalled for the purpose of substance storage unless:

(1) the tank is determined to be structurally sound through:

(a) thorough internal and external cleaning, degassing, and inspection;

or

(b) a leak test is conducted pursuant to item A, subitem (1); and

(2) the area of secondary containment which is directly under a tank is designed and constructed to provide for the detection of a release of a stored substance.

C. The following are exempt from the requirements of this subpart:

(1) portable tanks which are mounted on wheel carriages, which have legs cast into the construction, or which are mounted on forklift skids; and

(2) double-walled tanks.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## 7151.5300 LABELING.

Subpart 1. **Tanks.** Tanks must be clearly labeled indicating the substance stored and the tank's capacity. If there is more than one tank at a site, each tank must be labeled with a unique tank number.

Subp. 2. **Lines.** Lines used for loading and unloading a substance from a tank must be labeled so that the person controlling the substance transfer can readily identify which line is connected to which tank.

Subp. 3. **Sign.** A tank facility that does not have a person on site 24 hours a day must have a sign with the name, address, and telephone number of the facility owner, operator, or local emergency response. The sign must be posted in a conspicuous place and legible from outside any secondary containment area.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883



**7151.5400 SECONDARY CONTAINMENT.**

Subpart 1. **Requirement.** All tanks regulated by this chapter must have secondary containment. If tanks containing more than one type of substance are stored within one secondary containment area, the substances must be compatible with each other.

Subp. 2. **Volume.** A secondary containment area must be able to contain at least 100 percent of the design capacity of the largest tank in the secondary containment area plus displacement from additional tanks within the containment area, with an additional ten percent capacity where secondary containment areas are exposed to precipitation.

Subp. 3. **Materials.** A secondary containment area must be constructed with materials that are impermeable to and compatible with the substance being stored and that will prevent a release to the environment. Materials for secondary containment include:

- A. compacted clay as defined in subpart 5;
- B. geosynthetic clay liner;
- C. concrete for Type B and Type C substances. Concrete for Type A substances must be treated with a material that is impermeable to the substance being stored;
- D. synthetic membrane;
- E. the outer shell of a double-walled tank;
- F. the lower bottom of a double-bottomed tank;
- G. fabricated steel;
- H. fiberglass; or
- I. any other approved material having an impermeability equivalent to the stored substance's primary container, pursuant to the alternative design or operating practice procedure of part 7151.9400.

Owners and operators shall install and maintain secondary containment areas constructed of synthetic or manufactured materials according to the manufacturer's recommendations.

Subp. 4. **Design.** The area of secondary containment which is directly under a tank must be designed and constructed to provide for the detection of a release of a substance. Methods of leak detection are as follows:

- A. visual monitoring of:
  - (1) elevated tanks;
  - (2) tanks on continuous concrete slabs for Type B and Type C substances;
  - (3) tanks on a continuous concrete slab treated with material that is impermeable to the substance being stored for Type A substances;
  - (4) tanks on containment constructed of fabricated steel; or
  - (5) tanks on containment constructed of fiberglass;
- B. interstitial monitoring between the tank's inner and outer shell or the tank's shell and the containment area; or
- C. vapor monitoring in the soil directly under the tank bottom or perimeter and above the water table.

Subp. 5. **Clay.** A secondary containment area constructed of clay must:

- A. be used as an integral part of a geosynthetic clay liner; or
- B. meet the following standards:
  - (1) consist of a minimum of 12 inches of compacted imported clay or native clay soil;
  - (2) be protected with cover material to prevent drying and erosion;
  - (3) be designed, inspected, and certified by a registered professional engineer to prevent a release from the primary tank from extending outside the containment; and
  - (4) show, through postinstallation testing, that the compacted clay has a permeability rate to water equal to or less than  $1 \times 10^{-7}$  centimeters per second.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

# MINNESOTA RULES 2007

1539 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.5600

## 7151.5500 SUBSTANCE TRANSFER AREAS.

Subpart 1. **General.** Except as otherwise provided in subpart 2, owners or operators shall provide substance transfer safeguards. The safeguards, such as spill boxes, remote fill boxes, or containment areas must effectively contain a release at the connection point, as well as at the vehicle, during transfer of the substance to and from the tank.

Subp. 2. **Exclusions.** A substance transfer area safeguard is not required for:

- A. a tank that is filled with a hand-held nozzle;
- B. a transfer of the substance through a continuous pipeline between tanks at one site; or
- C. a barge transfer facility regulated under United States Coast Guard regulations, Code of Federal Regulations, title 33, parts 126, 154, and 156.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## 7151.5600 CORROSION PROTECTION.

Subpart 1. **Tanks.** The floor of a steel aboveground storage tank must be protected from corrosion using one of the following methods:

- A. the tank is elevated so that the underside of the tank floor is not in contact with any surface other than the tank supports;
- B. the tank rests on a continuous concrete slab that is designed to prevent water from accumulating under the tank floor;
- C. the tank is double walled;
- D. the tank is double-bottomed with:
  - (1) a vacuum pulled on the interstitial space; or
  - (2) a cathodic protection system installed in the interstitial space;
- E. the tank floor is:
  - (1) cathodically protected; and
  - (2) internally lined in accordance with American Petroleum Institute Standard 652;
- F. the tank floor is:
  - (1) cathodically protected; and
  - (2) internally inspected in accordance with American Petroleum Institute Standard 653; or
- G. the tank floor is:
  - (1) internally lined in accordance with American Petroleum Institute Standard 652; and
  - (2) internally inspected in accordance with American Petroleum Institute Standard 653.

Subp. 2. **Lines.** A steel line must be protected from external corrosion using one of the following methods:

- A. the line is not in contact with soil;
- B. the line is cathodically protected; or
- C. the line is double walled.

Subp. 3. **Design criteria.** Cathodic protection of new steel tanks and lines must meet the following design criteria:

- A. the cathodic protection system must be designed by a corrosion expert in accordance with American Petroleum Institute Standards 651 and 1632, as applicable; and
- B. underground lines and the underside of the floor of a shop-fabricated steel tank must be coated with dielectric material in accordance with Steel Tank Institute Recommended Practice R893-89.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

# MINNESOTA RULES 2007

## 7151.5700 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES

1540

### 7151.5700 OVERFILL PROTECTION.

Subpart 1. **Requirement.** A tank which is filled by transfers of more than 55 gallons at one time must have one of the following systems for overfill protection:

A. a high-level alarm, set at no greater than 95 percent of the tank's capacity, that is visible or audible to the person controlling the substance transfer;

B. a system that automatically shuts off the flow of substance into the tank, set at no greater than 95 percent of the tank's capacity;

C. a permanently mounted sight glass or gauge, visible to the person controlling the substance transfer, that accurately shows the level of substance in the tank; or

D. a person who manually gauges substance level with a level stick during substance transfer and controls the substance transfer or is in contact with a person who controls the substance transfer.

Subp. 2. **Double-walled tanks.** Double-walled tanks which are not otherwise located within a secondary containment area meeting the requirements of part 7151.5400 must have one of the following systems for overfill prevention:

A. a high-level alarm, set at no greater than 95 percent of the tank's capacity, that is visible or audible to the person controlling the substance transfer; or

B. a system that automatically shuts off the flow of substance into the tank, set at no greater than 95 percent of the tank's capacity.

Subp. 3. **Volumetric conversion.** If any level stick, sight glass, or gauge does not read in volumetric measurements and requires conversion, a clearly labeled conversion chart indicating maximum working capacity of the tank must be mounted on the tank or the tank's delivery manifold and visible to the person controlling the substance transfer.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## STANDARDS FOR EXISTING ABOVEGROUND STORAGE TANKS

### 7151.6100 REQUIREMENT.

Subpart 1. **Application.** Parts 7151.6100 to 7151.6700 apply to all aboveground storage tanks or tank systems installed prior to November 2, 1998, except as otherwise provided in subparts 2 and 3. For the purpose of parts 7151.6100 to 7151.6700, an existing tank or tank system is one installed prior to November 2, 1998.

Subp. 2. **Small tanks near surface water.** Owners and operators of tanks 1,100 gallons or less, but greater than 500 gallons and located within 500 feet of a Class 2 surface water, need not comply with parts 7151.6500, 7151.6600, and 7151.6700.

Subp. 3. **Tanks storing other regulated substances.** Owners and operators of tanks storing other regulated substances need not comply with parts 7151.6400, subpart 4, item A; 7151.6500; 7151.6600; and 7151.6700.

Subp. 4. **Tanks storing asphalt cement.** Owners and operators of tanks storing asphalt cement need not comply with parts 7151.6400, subpart 4, item A; 7151.6500; 7151.6600; and 7151.6700.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

### 7151.6200 TANK AND PIPING STANDARDS.

Subpart 1. **Tank and piping standards.** Owners and operators of aboveground storage tank systems shall ensure that existing systems used to store regulated substances will not structurally fail or corrode.

Subp. 2. **Underground storage tanks.** Tanks designed and constructed for service as underground storage tanks must not be used for aboveground storage.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

# MINNESOTA RULES 2007

1541 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.6400

## 7151.6300 LABELING.

All existing aboveground storage tank systems must meet the labeling requirements of part 7151.5300.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

## 7151.6400 SECONDARY CONTAINMENT.

### Subpart 1. Requirement.

A. Owners and operators must provide secondary containment for the storage of all substances in tanks. If more than one type of substance is stored within a single secondary containment area, the substances shall be compatible with each other and with the secondary containment area.

B. Secondary containment areas for existing aboveground storage tanks must have a continuous dike surrounding the tanks which will prevent releases from contaminating surface waters.

Subp. 2. **Volume.** All secondary containment systems for existing aboveground storage tanks must meet the volume requirements of part 7151.5400, subpart 2.

Subp. 3. **Materials.** All secondary containment systems for existing aboveground storage tanks must meet the materials requirements of subpart 5 or part 7151.5400, subpart 3.

### Subp. 4. Design.

A. If the tank is lifted or moved within a facility, the secondary containment system must meet the design requirements of part 7151.5400, subpart 4.

B. If the tank is moved from a facility and reinstalled on a second facility, the tank must meet the standards for new aboveground storage tanks in part 7151.5100.

Subp. 5. **Soils.** A secondary containment area constructed of soils must:

A. be used as an integral part of a geosynthetic clay liner; or

B. show, through testing, a permeability rate to water equal to or less than the following:

Substance Classification	Groundwater or Bedrock < 10 Feet from Grade or Class 2 Surface Water within 100 Feet of Aboveground Storage Tank	Groundwater and Bedrock ≥ 10 Feet from Grade and Class 2 Surface Water not within 100 Feet of Aboveground Storage Tank
Type A	Minimum of three feet of soil at $1 \times 10^{-5}$ cm/sec	Minimum of three feet of soil at $1 \times 10^{-4}$ cm/sec
Type B	Minimum of three feet of soil at $1 \times 10^{-4}$ cm/sec	Minimum of three feet of soil at $1 \times 10^{-3}$ cm/sec
Type C	Minimum of three feet of soil at $1 \times 10^{-3}$ cm/sec	No minimum permeability standard

Subp. 6. **Containment area evaluation.** Owners and operators shall perform post-installation permeability testing on containment areas constructed of native soils, amended soils, or imported clay liners requiring a minimum permeability standard under subpart 5. A qualified soil technician or testing company shall evaluate the top three feet of soil, below any cover material, for vertical soil permeability. Evaluation must:

A. comport with approved ASTM standard field or lab sampling techniques;

B. utilize the soil sampling matrix below to quantify permeability rates of soils in smaller containment areas:

# MINNESOTA RULES 2007

## 7151.6400 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES

1542

Secondary Containment Area Size (Square Feet)	Minimum Number of Soil Samples Necessary
<10,000	3
10,000 – 50,000	4
>50,000	Equal to the number of tanks contained in the secondary containment basin (minimum of 4 samples); and

C. utilize at least one sample collected from the lowest point in the containment area with the remaining samples triangulated across the entire basin.

### Subp. 7. **Timing of compliance.**

A. Owners and operators shall comply with subpart 1, item B, effective November 1, 1998.

B. Owners and operators shall comply with subparts 2 to 6, effective November 1, 2003.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## 7151.6500 SUBSTANCE TRANSFER AREAS.

Subpart 1. **General.** Owners and operators shall provide, for all tank systems, substance transfer safeguards such as spill boxes, remote fill boxes, or containment areas. The safeguards must effectively contain a release at the connection point, as well as at the vehicle, during transfer of the substance to and from the tank.

Subp. 2. **Exclusions.** A substance transfer area is not required for:

A. a tank that is filled with a hand-held nozzle;

B. a transfer of the substance through a continuous pipeline between tanks at one site; or

C. a barge transfer facility regulated under United States Coast Guard regulations, Code of Federal Regulations, title 33, parts 126, 154, and 156.

Subp. 3. **Timing of compliance.** Owners and operators shall comply with subpart 1 after one year following November 2, 1998.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## 7151.6600 CORROSION PROTECTION.

Subpart 1. **General.** Owners and operators shall apply corrosion protection to all steel tanks and tank systems except as otherwise provided in subpart 5.

Subp. 2. **Tanks.** The floor of an existing steel aboveground storage tank must be protected from external corrosion using one or more of the following methods:

A. the tank is elevated so that the underside of the tank's floor is not in contact with any surface other than the supports;

B. the tank rests on a continuous concrete slab that is designed to prevent water from accumulating under the tank floor;

C. the tank is double walled;

D. the tank is double-bottomed with:

(1) a vacuum pulled on the interstitial space; or

(2) a cathodic protection system installed in the interstitial space;

E. the tank floor is:

(1) cathodically protected; and

(2) internally lined in accordance with American Petroleum Institute Standard 652;

# MINNESOTA RULES 2007

1543

## ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.7100

F. the tank floor is:

- (1) cathodically protected; and
- (2) internally inspected in accordance with American Petroleum Institute Standard 653 prior to November 1, 2003, and thereafter as indicated by the results of the inspection; or

G. the tank floor is:

- (1) internally lined in accordance with American Petroleum Institute Standard 652; and
- (2) internally inspected in accordance with American Petroleum Institute Standard 653.

Subp. 3. **Lines.** An existing steel line must be protected from external corrosion using one or more of the following methods:

- A. the line is not in contact with soil;
- B. the underground line is cathodically protected; or
- C. the underground line is double walled.

Subp. 4. **Design criteria.** Cathodic protection of existing steel tanks and lines must be designed by a corrosion expert in accordance with American Petroleum Institute Standards 651 and 1632, as applicable.

Subp. 5. **Exclusions.** A secondary containment area for tanks or tank systems which complies with the requirements of part 7151.5400, subparts 1, 2, 3, items B to I, and 4, is excluded from the requirements of this part.

Subp. 6. **Timing of compliance.** Owners and operators shall comply with this part effective November 1, 2003.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

### 7151.6700 OVERFILL PROTECTION.

Subpart 1. **General.** Except as otherwise provided in subpart 2, owners and operators shall provide overfill protection, as provided in part 7151.5700, for all tank systems.

Subp. 2. **Exclusions.** A secondary containment area for tanks or tank systems which is constructed to a  $1 \times 10^{-7}$  centimeters per second permeability standard and meets the requirements of part 7151.5400 or 7151.6400, subparts 1 to 4, is excluded from the requirements of this part.

Subp. 3. **Timing of compliance.** Effective November 1, 2003, overfill protection shall be implemented pursuant to part 7151.5700.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## OPERATION AND MAINTENANCE OF ABOVEGROUND STORAGE TANKS

### 7151.7100 REQUIREMENT.

Subpart 1. **Application.** Parts 7151.7100 to 7151.7500 apply to all aboveground storage tank systems in use on or after November 2, 1998, except as otherwise provided in subpart 2.

Subp. 2. **Exclusions.** The following aboveground storage tanks are excluded from the requirements of parts 7151.7100 to 7151.7500:

A. tanks 1,100 gallons or less but greater than 500 gallons and located within 500 feet of Class 2 surface water;

B. tanks storing other regulated substances are excluded from part 7151.7200, subparts 4; 6, item B; and 7 only; and

C. tanks storing asphalt cement are excluded from part 7151.7200, subparts 4; 6, item B; and 7 only.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

**7151.7200 MONITORING.**

Subpart 1. **Transfer.** At least one person must be present during substance loading or unloading of a tank to visually monitor and terminate the transfer. The person monitoring the substance transfer shall take immediate action to stop the flow of the substance being transferred when the capacity of the tank has been reached or in the event of an equipment failure or emergency. Tank owners and operators shall recover all contaminated soils and any substance released during transfer.

Subp. 2. **Weekly monitoring.** Owners or operators of tanks shall conduct visual monitoring as described in items A to C to verify that no releases have occurred from the tank system.

A. If the secondary containment area complies with the standard established in part 7151.5400, the owner or operator shall visually monitor an aboveground storage tank site at least weekly.

B. If the secondary containment area does not comply with the standard established in part 7151.5400, the owner or operator shall visually monitor an aboveground storage tank site at least every 72 hours.

C. Owners and operators of double-walled tanks need not conduct weekly monitoring of the containment area around the double-walled tanks.

Subp. 3. **Monthly monitoring.** The owner or operator shall visually inspect tank systems at least monthly, including:

A. walking through the site to identify cracks or other defects in the secondary containment area and any substance transfer area;

B. a visual examination of the exterior surfaces of tanks, piping, valves, pumps, and other equipment for cracks, corrosion, releases, and maintenance deficiencies; and

C. identification of poor maintenance, operating practices, or malfunctioning equipment.

Subp. 4. **Leak detection.** The owner or operator shall monitor tank systems for leaks as described in items A to C. Any suspected releases shall be investigated and resolved.

A. If a tank is designed pursuant to part 7151.5400, subpart 4, leak detection must be conducted at least monthly as follows:

(1) visual monitoring of:

(a) elevated tanks;

(b) tanks on continuous concrete slabs for Type B and Type C substances;

(c) tanks on a continuous concrete slab treated with material that is impermeable to the substance being stored for Type A substances;

(d) tanks on containment constructed of fabricated steel; or

(e) tanks on containment constructed of fiberglass;

(2) interstitial monitoring between the tank's inner and outer shell or the tank's shell and the containment area; or

(3) vapor monitoring in the soil directly under the tank bottom or perimeter and above the water table.

B. If a tank is not designed pursuant to part 7151.5400, subpart 4, leak detection must be conducted at least monthly using one or more of the following:

(1) monthly reconciliation of substance measurements taken pursuant to the interval established in subpart 2, with dispenser meter readings, shipments, deliveries, and internal transfers; any difference of 2.0 percent or more of monthly throughput shall be investigated and resolved; or

(2) statistical inventory reconciliation as approved by the agency.

C. All underground lines must be tested for leaks at least annually using one or more of the following methods:

(1) tracer gas;

(2) hydrostatic;

# MINNESOTA RULES 2007

1545      **ABOVEGROUND STORAGE OF LIQUID SUBSTANCES**      7151.7300

- (3) lockdown pressure;
- (4) double-walled piping with a sump sensor connected to an audible alarm;

or

- (5) other approved methods pursuant to part 7151.9400.

Subp. 5. **Annual equipment check.** Owners and operators shall maintain in functioning condition all equipment used for release detection, monitoring, or warning. Owners and operators shall check such equipment for proper function or calibration at least yearly or in accordance with manufacturer's guidance.

Subp. 6. **Tank inspection.** All field-erected steel tanks must be internally and externally inspected by a certified tank inspector pursuant to American Petroleum Institute standard 653. Initial inspections must be completed in accordance with the following schedule:

A. external inspections shall be conducted by November 2, 2003, or a maximum of five years after the initial construction date, whichever is later; and

B. internal inspections shall be conducted by November 2, 2008, or a maximum of ten years after the initial construction date, whichever is later.

Subp. 7. **Corrosion protection monitoring.**

A. A qualified cathodic protection tester shall inspect all cathodic protection systems on steel tanks and piping as follows:

(1) all cathodic protection systems must be tested pursuant to the National Association of Corrosion Engineers RP-02-85 code of practice within six months of installation and at least every three years thereafter; and

(2) impressed current systems must be inspected for proper function every 60 days.

B. A lined tank which does not have external cathodic protection must be internally inspected within ten years after lining, and every ten years after that. The liner must be structurally sound with the lining performing pursuant to original design specifications.

C. If corrosion protection monitoring conducted in conformance with this part indicates inadequate corrosion protection, corrective measures must be taken within 180 days to ensure that the measured surface potential conforms to the requirements of this part.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

## 7151.7300 MAINTENANCE.

Subpart 1. **Tank.**

A. Owners and operators shall minimize rust on the tank exterior so as to not jeopardize the integrity of the tank system.

B. Owners and operators shall dispose of water that is drawn from the bottom of a tank according to applicable state and federal laws.

Subp. 2. **Containment safeguards.** Tank owners and operators shall maintain the integrity of containment safeguards as follows:

A. the secondary containment and substance transfer areas must be maintained free of cracks, open seams, open drains, siphons, and vegetation other than grass;

B. precipitation must be removed as often as practical to ensure proper containment volume; and

C. tank owners and operators shall reduce the storage volume within the tank or tank system to accommodate decreased secondary containment volume if accumulation of precipitation reduces the volume of the containment basin below 100 percent.

Subp. 3. **Storm water discharge.** Storm water that collects within the secondary containment area or substance transfer area must be discharged in compliance with all applicable state and federal laws.

Subp. 4. **Schedules.** Safeguard systems must be installed and maintained pursuant to applicable manufacturer's schedules and applicable standards.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883



**7151.7400 RECORDS.**

Subpart 1. **Application.** Owners and operators of tanks shall retain information, reports, and records according to this part. Upon agency request, tank owners and operators shall make such data available to the agency for viewing and copying.

**Subp. 2. Tank system design.**

A. Except as specified in item C, the owner and operator shall retain, for the life of the tank system, the following records which are available as of November 2, 1998:

- (1) maintenance and repair documentation;
- (2) third-party certifications of tank system equipment; and
- (3) as-built drawings.

B. As-built drawings must be maintained by the owner or operator of all field-erected tank installations conducted after November 2, 1998. The drawings shall be certified by a professional engineer and illustrate:

- (1) the tank foundation;
- (2) the tank bottom design; and
- (3) the volume and design of the secondary containment basin, including the dike walls and the area directly under the tank.

C. Owners and operators shall retain for three years all documentation addressing service check and equipment calibrations.

Subp. 3. **Containment area evaluation.** Owners and operators of tanks shall retain, for the life of the tank system, the following written records of all sampling and testing methods used to evaluate permeability of soil containment areas:

- A. classification of soils used in containment area construction;
- B. soil descriptions and logs of each sample location;
- C. a table of individual permeability tests; and
- D. hydraulic conductivity of the soil expressed as centimeters per second for each sample location and for each containment area.

**Subp. 4. Monitoring.**

A. Owners and operators of tanks shall retain, for at least three years from the date of the activity, the written records of all periodic monitoring activities. The person performing the monitoring activity shall document the following information:

- (1) the name of the person doing the monitoring;
- (2) the monitoring method or methods used;
- (3) the date of the monitoring; and
- (4) the results of the monitoring.

B. Owners and operators shall retain, for the life of the tank, documentation of corrosion protection and internal tank inspections and a written summary of the results.

C. Owners and operators shall retain, for three years after the tank has been taken out of service, records demonstrating compliance with out-of-service tank requirements under parts 7151.8100 to 7151.8500. Records must be retained in one of the following ways:

- (1) by the owners and operators who took the aboveground storage tank system out of service;
- (2) by the current owners and operators of the site; or
- (3) by mailing the records to the agency if they cannot be retained at the closed facility.

D. Upon agency request, owners and operators of tanks shall make data available to the agency for viewing and copying.

Subp. 5. **Tank inspection.** Owners and operators of tanks shall retain, for the life of the tank system, the written records of all internal and external tank inspections.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

# MINNESOTA RULES 2007

1547 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.8200

## 7151.7500 RELEASES AND DISCHARGES TO A SECONDARY CONTAINMENT AREA.

Subpart 1. **Release investigation.** An owner or operator shall immediately investigate a suspected release or discharge to a secondary containment area.

Subp. 2. **Assessment of secondary containment area following release.** The owner or operator shall assess for damage any secondary containment area where there was a release of a stored substance from an aboveground storage tank into a secondary containment area. The owner or operator shall repair the secondary containment area pursuant to part 7151.5400 or 7151.6400, as applicable, prior to continued substance storage.

Subp. 3. **Reporting.** An owner or operator shall notify the agency immediately of discharges to a secondary containment area, including those associated with substance transfer areas, in conformance with the requirements of Minnesota Statutes, section 115.061.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## WITHDRAWAL FROM SERVICE OF ABOVEGROUND STORAGE TANK SYSTEMS

### 7151.8100 REQUIREMENT.

Parts 7151.8100 to 7151.8500 address procedures for aboveground storage tank system's out-of-service status, reactivation, and contamination analysis.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

### 7151.8200 OUT-OF-SERVICE ABOVEGROUND STORAGE TANK SYSTEMS.

Subpart 1. **Application.** If a substance is not introduced to or removed from an aboveground storage tank system for one year or more, or if an aboveground storage tank system is to be permanently closed, the owner or operator shall:

A. maintain the operation and maintenance requirements of parts 7151.7100 to 7151.7500; or

B. declare the tank system as inactive and taken out of service or removed.

Subp. 2. **Out of service.** The owner or operator of an aboveground storage tank system taken out of service shall:

A. remove all substances from the aboveground storage tank, connected piping, and appurtenances;

B. secure the aboveground storage tank to prevent unauthorized entrance or tampering, by:

(1) securely bolting and locking all manways and valves; and

(2) capping or plugging fill lines, gauge openings, or pump lines;

C. thoroughly clean the interior of the tank and all associated piping of all sludge, solids, and residuals;

D. dispose of tank bottom sludges in accordance with applicable state or federal requirements;

E. render the tank sufficiently free of vapors to avoid formation of an explosive atmosphere and vent the tank; and

F. clearly label the exterior of an out-of-service tank with the words "Out of Service," and the date the tank was taken out of service.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

# MINNESOTA RULES 2007

## 7151.8300 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES

1548

### 7151.8300 REACTIVATING OUT-OF-SERVICE ABOVEGROUND STORAGE TANK SYSTEMS.

The owner or operator shall, prior to placing an inactive aboveground storage tank system back into service, thoroughly inspect and test the aboveground storage tank system pursuant to part 7151.5200, subpart 3.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

### 7151.8400 CONTAMINATION DETERMINATION.

Subpart 1. **Application.** Except as otherwise provided in subpart 2, owners and operators shall sample for contamination when removing a tank and determine, through laboratory analysis, the extent of contamination. In selecting sample types, sample locations, and measurement methods, owners and operators shall consider:

- A. the method of closure;
- B. the nature of the stored substance;
- C. the type of secondary containment;
- D. the depth to groundwater;
- E. areas having the greatest potential for contamination; and
- F. other factors necessary for identifying the presence of a release.

Subp. 2. **Exclusions.** The following aboveground storage tank systems are excluded from the requirements of this part:

- A. a tank storing other regulated substances;
- B. a tank, which has been removed, that exclusively contained number 6 grade fuel oil or asphalt cement; and
- C. a tank with containment under the tank floor meeting part 7151.5400, subpart 3, item C, D, E, G, H, or I where:
  - (1) there is no evidence of a release through visual evidence, odor, operating history; and
  - (2) there is no compromise of the integrity of the containment.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883; 25 SR 556

### 7151.8500 CONTAMINATION DETERMINATION FOR PREVIOUSLY CLOSED ABOVEGROUND STORAGE TANK SYSTEMS.

If a release from an aboveground storage tank system taken out of service before November 2, 1998, poses a current or potential threat to human health or the environment, the commissioner shall direct the owner and operator to assess the extent of the contamination and close the aboveground storage tank system pursuant to this part.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

## MISCELLANEOUS

### 7151.9100 INADEQUATE SAFEGUARDS.

The owner or operator shall immediately remove a substance from an aboveground storage tank failing to meet the requirements of this chapter. The owner or operator shall refrain from further use of the aboveground storage tank until the tank or tank system complies with all applicable requirements of this chapter.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

# MINNESOTA RULES 2007

1549

ABOVEGROUND STORAGE OF LIQUID SUBSTANCES 7151.9400

## 7151.9200 PROCEDURAL RULES AND APPEALS.

A request for a hearing, an appeal, or other procedural matter not specifically provided for in this chapter is governed by rules of procedure, chapter 7000; the rules of the Office of Administrative Hearings, chapter 1400; and other applicable laws.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

## 7151.9300 VARIANCES.

Any person who applies for a variance from any requirement of this chapter shall comply with part 7000.7000. An application for a variance must be acted on by the agency pursuant to part 7000.7000 and Minnesota Statutes, section 116.07, subdivision 5. However, no variance may be granted that would result in noncompliance with applicable federal rules and regulations for aboveground storage tanks.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

## 7151.9400 ALTERNATIVE DESIGN OR OPERATING PRACTICE.

Subpart 1. **General.** An owner or operator may submit a petition to the commissioner for approval to use an alternative design or operating practice in lieu of the requirements of this chapter.

### Subp. 2. **Petition.**

A. Each petition for approval to use an alternative design or operating practice must include:

- (1) the petitioner's name and address;
- (2) a statement of the petitioner's interest in the proposed action;
- (3) a full description of the proposed method, including all procedural steps and equipment used in the method;
- (4) comparative results obtained from using the proposed method with those obtained from using the relevant or corresponding methods in this chapter;
- (5) an assessment of any factors which may interfere with, or limit the use of, the proposed method; and
- (6) a description of the quality control procedures necessary to ensure the efficacy of the proposed method.

B. After receiving a petition for approval to use an alternative design or operating practice, the commissioner shall request any additional information on the proposed method which the commissioner reasonably requires to evaluate the method.

Subp. 3. **Procedure for petition review.** The commissioner's determination to approve or deny an alternative design or operating practice petition shall be based on a demonstration by the petitioner that the alternative design or operating practice, together with location characteristics, will prevent migration of stored substances into surface water and groundwater as effectively as the requirements of this chapter and will not endanger human health or the environment.

A. In approving or denying the petition, the commissioner shall consider:

- (1) the nature, toxicity, viscosity, and quantity of the product;
- (2) the technical feasibility of the proposed alternative design and operating practice;
- (3) the hydrogeologic setting of the facility, including the thickness of soils present between the tank system and groundwater;
- (4) factors that would influence the quality and mobility of the stored substance and the potential for it to migrate to surface water or groundwater; and
- (5) any other factor necessary to determine equivalent protection.

# MINNESOTA RULES 2007

## 7151.9400 ABOVEGROUND STORAGE OF LIQUID SUBSTANCES

1550

Subp. 4. **Compliance.** The owner or operator shall comply with the approval of petition for alternative design or operating practice and all terms and conditions imposed on the approval of petition for alternative design or operating practice.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

## 7151.9500 RELEASE REPORTING.

Nothing in this chapter shall relieve an owner or operator from compliance with any state, federal, or local duty to report.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*

## 7151.9600 OTHER REGULATIONS.

Subpart 1. **General.** This chapter shall be in addition to the standards imposed by any other regulations applying to aboveground storage tanks.

Subp. 2. **Permit preemption.** This chapter supersedes all terms and conditions of permits issued to tank owners and operators pursuant to chapter 7100.

**Statutory Authority:** *MS s 115.03*

**History:** *23 SR 883*