

CHAPTER 7678
DEPARTMENT OF COMMERCE
ENERGY CODE; EFFICIENCIES, CALCULATIONS

| | |
|---|---|
| <p>THERMAL TRANSMITTANCE CALCULATIONS FOR OPAQUE ENVELOPE COMPONENTS; HVAC SPECIFIC EFFICIENCIES</p> <p>7678.0100 AUTHORITY AND PURPOSE. 7678.0200 APPLICATION. 7678.0300 INCORPORATIONS BY REFERENCE. 7678.0400 DEFINITIONS.</p> | <p>7678.0500 ENVELOPE THERMAL TRANSMITTANCE CALCULATIONS. 7678.0600 FENESTRATION PRODUCTS. 7678.0700 MECHANICAL EQUIPMENT EFFICIENCY REQUIREMENTS. 7678.0800 SERVICE WATER HEATING EQUIPMENT EFFICIENCY REQUIREMENTS. 7678.0900 EFFECTIVE DATE.</p> |
|---|---|

NOTE: This chapter was adopted at 23 SR 145 on July 20, 1998. It became effective on July 20, 1999; however, chapter 7670 remains in effect. Laws 2000, chapter 407, section 1.

THERMAL TRANSMITTANCE CALCULATIONS FOR OPAQUE ENVELOPE COMPONENTS; HVAC SPECIFIC EFFICIENCIES

7678.0100 AUTHORITY AND PURPOSE.

This chapter is adopted pursuant to Minnesota Statutes, section 216C.19, subdivision 8. The purpose of this chapter is to provide a basis for thermal transmittance calculations for opaque envelope components for determining energy code compliance as required in chapters 7670, 7672, and 7674. This chapter also provides specific efficiencies for heating, ventilating, and air conditioning equipment and service water heating equipment.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0200 APPLICATION.

This chapter applies to buildings and equipment covered by chapters 7670, 7672, 7674, and 7676.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0300 INCORPORATIONS BY REFERENCE.

Subpart 1. **Incorporated items.** The following standards and references are incorporated by reference:

- A. ASHRAE, 1997 Handbook of Fundamentals, chapters 25 to 28;
- B. Code of Federal Regulations, title 10, part 430, Energy Conservation Program for Consumer Products;
- C. Code of Federal Regulations, title 10, part 435, Energy Conservation Voluntary Performance Standards for New Commercial and Multi-Family High Rise Residential Buildings Mandatory for New Federal Buildings;
- D. ASTM C236-89 (1993)e1, Steady-State Thermal Performance of Building Assemblies by Means of a Guarded Hot Box;
- E. ASTM C976-90 (1996)e1, Thermal Performance of Building Assemblies by Means of a Calibrated Hot Box;
- F. NFRC 100-91, Procedure for Determining Fenestration Product Thermal Properties (Currently Limited to U-values), and NFRC 100 (1997 ed.), Procedure for Determining Fenestration Product U-Factors, National Fenestration Rating Council;
- G. NFRC 200, Procedure for Determining Fenestration Product Solar Heat Gain Coefficients at Normal Incidence (1995), National Fenestration Rating Council; and

H. ASTM E283-91, Standard Method of Test for Rate of Air Leakage through Exterior Windows, Curtain Walls, and Doors.

Subp. 2. **Availability.** All standards and documents incorporated by reference are available for public inspection at the Minnesota State Law Library and through the Minitex interlibrary loan system.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0400 DEFINITIONS.

Subpart 1. **Definitions.** The definitions in this part apply to this chapter.

Subp. 2. **Annual fuel utilization efficiency or AFUE.** "Annual fuel utilization efficiency" or "AFUE" means the efficiency descriptor for furnaces and boilers determined using test procedures prescribed in Code of Federal Regulations, title 10, part 430.

Subp. 3. **Boiler capacity.** "Boiler capacity" means the rate of heat output in Btu/h measured at the boiler outlet, at the design inlet and outlet conditions, and rated fuel/energy input.

Subp. 4. **Efficiency, combustion or Ec.** "Efficiency, combustion" or "Ec" means 100 percent minus flue loss.

Subp. 5. **Efficiency, thermal or Et.** "Efficiency, thermal" or "Et" means the results of a thermal efficiency test referenced in Code of Federal Regulations, title 10, part 430 or 435.

Subp. 6. **Energy efficiency ratio or EER.** "Energy efficiency ratio" or "EER" means the ratio of net equipment cooling capacity in Btu/h to total rate of electric input in watts under designated operating conditions, as determined by Code of Federal Regulations, title 10, part 430 or 435.

Subp. 7. **Heating degree day.** "Heating degree day" means a unit, based upon temperature difference and time, used in estimating fuel consumption and specifying nominal heating load of a building in winter. For any one day, when the mean temperature is less than 65 degrees Fahrenheit, there exist as many degree days as there are Fahrenheit degrees difference in temperature between the mean temperature for the day and 65 degrees Fahrenheit.

Subp. 8. **Heating seasonal performance factor or HSPF.** "Heating seasonal performance factor" or "HSPF" means the total heating output of a heat pump during its normal annual usage period for heating, in Btu, divided by the total electric energy input during the same period, in watt-hours, as determined by Code of Federal Regulations, title 10, part 435.

Subp. 9. **Integrated part load value or IPLV.** "Integrated part load value" or "IPLV" means a single number figure of merit for air-conditioning and heat pump equipment based on weighted operation at a set of less than full capacities for the equipment, as determined by Code of Federal Regulations, title 10, part 435.

Subp. 10. **Once-through system.** "Once-through system" means an HVAC or refrigeration system used for any type of temperature or humidity control application using groundwater that circulates through the system and is then discharged without reusing it for a higher priority purpose.

Subp. 11. **Roof/ceiling assembly.** "Roof/ceiling assembly" means the surface area of all components of the roof/ceiling envelope through which heat flows, thus creating a building transmission heat loss or gain, where such assembly is exposed to outdoor air and encloses a conditioned or semiconditioned space.

Subp. 12. **Seasonal energy efficiency ratio or SEER.** "Seasonal energy efficiency ratio" or "SEER" means the total cooling output of an air conditioner during its normal annual usage period for cooling, in Btu/h, divided by the total electric energy input during the same period in watt hours, as determined by Code of Federal Regulations, title 10, part 430 or 435.

MINNESOTA RULES 2003

845

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

Subp. 13. **Thermal resistance or R.** “Thermal resistance” or “R” means the reciprocal of thermal transmittance ($\text{h ft}^2 \text{ }^\circ\text{F/Btu}$).

Subp. 14. **Thermal transmittance or U.** “Thermal transmittance” or “U” means the coefficient of heat transmission (air-to-air). Thermal transmittance is the time rate of heat flow per unit area and unit temperature differential between the warm side and cold side of air films ($\text{Btu/h ft}^2 \text{ }^\circ\text{F}$).

Subp. 15. **Thermal transmittance, overall or U_o .** “Thermal transmittance, overall” or “ U_o ” means the overall thermal transmittance of an exterior building envelope component, such as a wall, floor, or roof/ceiling. The value of U_o is calculated by the parallel path heat flow method using the areas and thermal transmittance values of the various elements, such as windows, doors, and opaque surfaces that comprise the gross area of the building component.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0500 ENVELOPE THERMAL TRANSMITTANCE CALCULATIONS.

Subpart 1. **General.** The thermal transmittance of thermal envelope components must be determined in accordance with this part.

Subp. 2. **Overall thermal transmittance.** Overall thermal transmittance must be determined in accordance with this subpart. The parallel heat flow U_o is the area weighted average of the thermal transmittance of the components of an overall assembly.

The equation for thermal transmittance of an assembly is as follows:

$$U_o = (A_1/R_1 + A_2/R_2 + A_3/R_3 + \dots)/A_o$$

Where:

A_1, A_2, A_3, \dots = the cross-sectional area of the different elements, such as opaque walls, windows, and doors

R_1, R_2, R_3, \dots = the cross-sectional R-value of the different elements

A_o = the gross area of the element or overall assembly

Subp. 3. **Thermal transmittance of opaque building components.** Thermal transmittance of opaque building components must be determined according to this subpart.

EXCEPTION: Calculations performed by a professional engineer registered in Minnesota according to the procedures in the ASHRAE Handbook of Fundamentals, Chapter 27.

A. When return air ceiling plenums are employed, the roof/ceiling assembly must:

(1) for thermal transmittance purposes, not include the ceiling proper nor the plenum space as part of the assembly; and

(2) for gross area purposes, be based upon the interior face of the upper plenum surface.

B. Calculation of overall thermal transmittance for framed walls must be based upon the percentage of wall area in this item.

FRAMING AREA FACTORS FOR LOAD BEARING STUD WALLS

| Stud Spacing | Studs and Headers | Insulated Cavity |
|--------------|-------------------|------------------|
| 16 inches | 23 percent | 77 percent |
| 24 inches | 17 percent | 83 percent |

MINNESOTA RULES 2003

FRAMING AREA FACTORS FOR BLOCK WALLS WITH WOOD STUD FURRING

| Stud Spacing | Studs and Headers | Insulated Cavity |
|--------------|-------------------|------------------|
| 16 inches | 12 percent | 88 percent |
| 24 inches | 9 percent | 91 percent |

C. The proposed design may take into account the thermal mass of the building components in considering energy conservation. This applies only for walls in locations with less than 8,000 heating degree days and a base temperature of 65 degrees Fahrenheit with a heat capacity equal to or exceeding 6.0 Btu/ft² °F. The required wall thermal transmittance is adjusted according to the table in this item.

| Required Value of U _w without Consideration of Thermal Mass | Required Value of U _w with Consideration of Mass (position of insulation) | | |
|--|--|-----------------------|-------------------------|
| | Exterior of wall mass | Interior of wall mass | Integral with wall mass |
| 0.20 | 0.22 | 0.21 | 0.22 |
| 0.18 | 0.20 | 0.19 | 0.20 |
| 0.16 | 0.18 | 0.17 | 0.18 |
| 0.14 | 0.15 | 0.14 | 0.16 |
| 0.12 | 0.13 | 0.13 | 0.13 |
| 0.10 | 0.11 | 0.10 | 0.11 |
| 0.08 | 0.09 | 0.08 | 0.09 |
| 0.06 | 0.07 | 0.06 | 0.07 |
| 0.04 | 0.05 | 0.04 | 0.05 |

D. Conversion to metric (SI) units.

| Unit of Measure | Multiply | By | To Obtain Metric Unit |
|-----------------------|---------------------------------------|-------|----------------------------------|
| Thermal transmittance | R-value (h • ft ² • F/Btu) | 0.578 | RSI-value (m ² • C/W) |
| Thermal conductance | U-value (Btu/h/ft ² •°F) | 1.73 | U-value (W/m ² •C) |
| Heat capacity | (Btu/lb/°F) | 0.43 | k/kg/°K |

Subp. 4. **Wood frame construction.** The thermal transmittance of wood frame construction must be determined by the parallel heat flow method in this subpart. The parallel heat flow U-value is the area weighted average of the thermal transmittance of the components of an assembly.

A. The equation for thermal transmittance of an assembly is as follows:

$$U = (A_1/R_1 + A_2/R_2 + A_3/R_3 + \dots)/A_o$$

Where:

A₁, A₂, A₃, . . . = the cross-sectional area of the different elements, such as framing and insulated cavities. Subpart 3, item B, must be used to calculate insulated and framing areas unless different values are shown by documentation

MINNESOTA RULES 2003

847

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

R_1, R_2, R_3, \dots = the cross-sectional R-value of the different elements

A_o = the gross area of the element or overall component

B. The U-values table for wood framed wall assemblies is as follows:

WOOD FRAMED WALL ASSEMBLIES

| Framing | Insulation | OSB or Plywood | 25/32 Fiberboard | With Foam Plastic Insulation Sheathing | | | |
|-----------------------------|------------|----------------|------------------|---|-------|--|-------|
| | | | | Extruded Polystyrene (in.) (R-5/inch minimum) | 1 | Poly-isocyanurate (in.) (foil-backed foam board) | 1 |
| | R-Value | Sheathing | Sheathing | 0.75 | 1 | 0.75 | 1 |
| Total Opaque Wall U-values* | | | | | | | |
| 2x4 | 13 | 0.074 | 0.067 | 0.060 | 0.056 | 0.055 | 0.050 |
| 16" | 15 | 0.067 | 0.061 | 0.055 | 0.052 | 0.051 | 0.046 |
| o.c.** | | | | | | | |
| 2x6 | 19 | 0.056 | 0.051 | 0.047 | 0.045 | 0.044 | 0.041 |
| 16" | 21 | 0.049 | 0.046 | 0.043 | 0.041 | 0.040 | 0.037 |
| o.c.** | | | | | | | |

*This U-value includes studs and insulated cavity as well as siding, sheathing, gypsum board, and air films.

**o.c. refers to "on center" spacing of studs, rafters, and trusses.

C. The U-values table for wood framed rim and band joists is as follows:

WOOD FRAMED RIM AND BAND JOISTS

| Rim/Band Joist Description | OSB or Plywood | 25/32 Fiberboard | With Foam Plastic Insulation Sheathing | | | |
|----------------------------|----------------|------------------|---|-------|--|-------|
| | | | Extruded Polystyrene (in.) (R-5/inch minimum) | 1 | Poly-isocyanurate (in.) (foil-backed foam board) | 1 |
| | Sheathing | Sheathing | 0.75 | 1 | 0.75 | 1 |
| Rim/Band Joist U-values* | | | | | | |
| 2x or TGI, R-13 batt | 0.074 | 0.067 | 0.060 | 0.056 | 0.055 | 0.050 |

MINNESOTA RULES 2003

7678.0500 ENERGY CODE; EFFICIENCIES, CALCULATIONS

848

| | | | | | | |
|-----------------------------|-------|-------|-------|-------|-------|-------|
| 2x or TGI, R-19 batt | 0.045 | 0.042 | 0.040 | 0.038 | 0.037 | 0.035 |
| 2x or TGI, R-21 batt | 0.042 | 0.039 | 0.037 | 0.035 | 0.035 | 0.033 |
| Floor truss**, R-13 batt | | | | | | |
| Floor truss**, R-19 batt | 0.053 | 0.049 | 0.045 | 0.043 | 0.042 | 0.039 |
| Floor truss**, R-21 batt | 0.048 | 0.045 | 0.042 | 0.040 | 0.039 | 0.037 |
| Floor truss, air seal*** | 0.061 | 0.056 | 0.051 | 0.048 | 0.047 | 0.043 |

*This U-factor includes floor joists or trusses and insulated cavity as well as siding, sheathing, and air films.

**These values are for bottom chord bearing trusses. For top chord bearing trusses, include the truss area as part of the framed wall.

***Air-sealed design incorporates 1-1/2 inches of polystyrene and 1-1/2 inches of polyisocyanurate board to form an air-vapor barrier.

D. Roof/ceiling assemblies with rafter, truss, or scissors truss construction is as follows:

| Loose Fill Insulation R-value | U-value |
|-------------------------------------|---------|
| 30 | 0.033 |
| 38 | 0.026 |
| 44 | 0.022 |
| 49 | 0.020 |

E. Roof/ceiling assemblies with cathedral ceiling (solid lumber, not truss framing) is as follows:

| Batt Insulation R-value | With R-5 Sheathing | Without Insulation Sheathing U-values |
|-------------------------------|-----------------------|---|
| 25 | 0.040 | 0.050 |
| 30 | 0.033 | 0.040 |
| 38 | 0.026 | 0.030 |

Subp. 5. **Masonry block walls.** To determine the thermal transmittance of masonry block walls with insulation inserts or filled cores, the series-parallel method must be used. The series-parallel transmittance calculation shall be deemed in compliance with this subpart if the product is certified under the National Concrete Masonry Association's Certification of Thermal Performance of Integrally Insulated Concrete Masonry Walls.

A. The series-parallel heat flow method is a procedure that accounts for the fact that heat does not always flow straight through a wall.

The equations for series-parallel thermal transmittance are as follows:

MINNESOTA RULES 2003

849

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

$$U = 1/R_o$$

$$R_o = \frac{1}{\frac{a_{11}}{R_{11}} + \frac{a_{12}}{R_{12}} + \dots + \frac{a_{1p}}{R_{1p}}} + \dots + \frac{1}{\frac{a_{n1}}{R_{n1}} + \frac{a_{n2}}{R_{n2}} + \dots + \frac{a_{np}}{R_{np}}} + R_{film}$$

Where:

R_o = total thermal resistance of the representative concrete masonry wall, including surface air film resistances.

a_{11} = proportionate area of thermal path number 1 of thermal layer number 1.

R_{11} = thermal resistance of thermal path number 1 of thermal layer number 1.

a_{1p} = proportionate area of thermal path number "p" of thermal layer number 1.

R_{1p} = thermal resistance of thermal path number "p" of thermal layer number 1.

a_{np} = proportionate area of thermal path number "p" of thermal layer number "n".

R_{np} = thermal resistance of thermal path number "p" of thermal layer number "n".

R_{film} = thermal resistance of inside air film (0 mph) and outside air film (15 mph).

B. The U-value table for normal weight blocks is as follows:

Normal Weight Concrete Blocks (132 PCF) U-Value Table¹

Block Width:

12 Inches

Additional Insulation

| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
|---------------------------|------------|--------------------------------|-----------------|-------|-------|----------------|----------------------|
| | | | 0.75 | 1 | 2 | | |
| grouted | 0.51 | expanded ² | 0.20 | 0.17 | 0.10 | | 0.13 |
| grouted | 0.51 | extruded ³ | 0.16 | 0.13 | 0.081 | | |
| grouted | 0.51 | poly-isocyanurate ⁴ | 0.13 | 0.10 | 0.059 | | |
| grouted empty | 0.51 | fiberglass | | | | 0.083 | |
| empty | 0.45 | expanded | 0.19 | 0.16 | 0.101 | | 0.13 |
| empty | 0.45 | extruded | 0.16 | 0.13 | 0.079 | | |
| empty | 0.45 | poly-isocyanurate | 0.12 | 0.10 | 0.059 | | |
| empty filled ⁵ | 0.45 | fiberglass | | | | 0.081 | |
| filled | 0.20 | expanded | 0.12 | 0.11 | 0.080 | | 0.094 |
| filled | 0.20 | extruded | 0.11 | 0.097 | 0.065 | | |
| filled | 0.20 | poly-isocyanurate | 0.093 | 0.080 | 0.051 | | |
| filled | 0.20 | fiberglass | | | | 0.066 | |
| UFFI ⁶ | 0.19 | expanded | 0.12 | 0.11 | 0.078 | | 0.09 |
| UFFI | 0.19 | extruded | 0.11 | 0.094 | 0.064 | | |
| UFFI | 0.19 | poly-isocyanurate | 0.091 | 0.078 | 0.050 | | |
| UFFI | 0.19 | fiberglass | | | | 0.065 | |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

MINNESOTA RULES 2003

²Expanded is typically white “bead board” foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

Normal Weight Concrete Blocks (132 PCF) U-Value Table¹

Block Width:

10 Inches

Additional Insulation

| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
|---------------------|------------|--------------------------------|-----------------|-------|-------|-------------------|-------------------------|
| | | | 0.75 | 1 | 2 | | |
| grouted | 0.56 | expanded ² | 0.20 | 0.17 | 0.11 | | 0.076 |
| grouted | 0.56 | extruded ³ | 0.17 | 0.14 | 0.082 | | |
| grouted | 0.56 | poly-isocyanurate ⁴ | 0.13 | 0.11 | 0.060 | | |
| grouted | 0.56 | fiberglass | | | | 0.085 | |
| empty | 0.46 | expanded | 0.19 | 0.16 | 0.10 | | 0.073 |
| empty | 0.46 | extruded | 0.16 | 0.13 | 0.079 | | |
| empty | 0.46 | poly-isocyanurate | 0.12 | 0.102 | 0.059 | | |
| empty | 0.46 | fiberglass | | | | 0.082 | |
| filled ⁵ | 0.23 | expanded | 0.13 | 0.12 | 0.083 | | 0.100 |
| filled | 0.23 | extruded | 0.12 | 0.10 | 0.068 | | |
| filled | 0.23 | poly-isocyanurate | 0.098 | 0.083 | 0.052 | | |
| filled | 0.23 | fiberglass | | | | 0.069 | |
| UFFI ⁶ | 0.22 | expanded | 0.13 | 0.12 | 0.082 | | 0.062 |
| UFFI | 0.22 | extruded | 0.11 | 0.10 | 0.067 | | |
| UFFI | 0.22 | poly-isocyanurate | 0.10 | 0.082 | 0.051 | | |
| UFFI | 0.22 | fiberglass | | | | 0.068 | |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

²Expanded is typically white “bead board” foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

Normal Weight Concrete Blocks (132 PCF) U-Value Table¹

Block Width:

8 Inches

Additional Insulation

| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
|---------|------------|-----------------------|-----------------|------|------|-------------------|-------------------------|
| | | | 0.75 | 1 | 2 | | |
| grouted | 0.62 | expanded ² | 0.21 | 0.18 | 0.11 | | 0.014 |

MINNESOTA RULES 2003

851

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

| | | | | | | | |
|---------------------|------|--------------------------------|------|-------|-------|-------|------|
| grouted | 0.62 | extruded ³ | 0.17 | 0.14 | 0.083 | | |
| grouted | 0.62 | poly-isocyanurate ⁴ | 0.13 | 0.11 | 0.061 | | |
| grouted | 0.62 | fiberglass | | | | 0.086 | |
| empty | 0.48 | expanded | 0.19 | 0.16 | 0.103 | | 0.13 |
| empty | 0.48 | extruded | 0.16 | 0.13 | 0.080 | | |
| empty | 0.48 | poly-isocyanurate | 0.13 | 0.10 | 0.059 | | |
| empty | 0.48 | fiberglass | | | | 0.083 | |
| filled ⁵ | 0.27 | expanded | 0.14 | 0.13 | 0.088 | | 0.11 |
| filled | 0.27 | extruded | 0.13 | 0.11 | 0.070 | | |
| filled | 0.27 | poly-isocyanurate | 0.10 | 0.088 | 0.054 | | |
| filled | 0.27 | fiberglass | | | | 0.072 | |
| UFFI ⁶ | 0.25 | expanded | 0.14 | 0.12 | 0.086 | | 0.10 |
| UFFI | 0.25 | extruded | 0.12 | 0.11 | 0.069 | | |
| UFFI | 0.25 | poly-isocyanurate | 0.10 | 0.086 | 0.053 | | |
| UFFI | 0.25 | fiberglass | | | | 0.071 | |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

²Expanded is typically white "bead board" foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

C. The U-value tables for lightweight blocks are as follows:

Light Weight Concrete Blocks (100 PCF) U-Value Table¹

| Block Width: 12 Inches | | | Additional Insulation | | | | |
|---------------------------|------------|--------------------------------|-----------------------|-------|-------|-------------------|-------------------------|
| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
| | | | 0.75 | 1 | 2 | | |
| grouted | 0.42 | expanded ² | 0.18 | 0.16 | 0.10 | | 0.12 |
| grouted | 0.42 | extruded ³ | 0.15 | 0.13 | 0.078 | | |
| grouted | 0.42 | poly-isocyanurate ⁴ | 0.12 | 0.10 | 0.058 | | |
| grouted | 0.42 | fiberglass | | | | 0.080 | |
| empty | 0.37 | expanded | 0.17 | 0.15 | 0.097 | | 0.12 |
| empty | 0.37 | extruded | 0.15 | 0.12 | 0.076 | | |
| empty | 0.37 | poly-isocyanurate | 0.12 | 0.097 | 0.057 | | |
| empty | 0.37 | fiberglass | | | | 0.078 | |
| filled ⁵ | 0.12 | expanded | 0.089 | 0.082 | 0.063 | | 0.072 |
| filled | 0.12 | extruded | 0.081 | 0.074 | 0.054 | | |
| filled | 0.12 | poly-isocyanurate | 0.072 | 0.063 | 0.044 | | |
| filled | 0.12 | fiberglass | | | | 0.054 | |
| UFFI ⁶ | 0.11 | expanded | 0.083 | 0.077 | 0.060 | | 0.068 |
| UFFI | 0.11 | extruded | 0.076 | 0.069 | 0.052 | | |
| UFFI | 0.11 | poly- | 0.068 | 0.060 | 0.042 | | |

MINNESOTA RULES 2003

| | | | |
|------|------|--------------|-------|
| | | isocyanurate | |
| UFFI | 0.11 | fiberglass | 0.052 |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

²Expanded is typically white “bead board” foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

Light Weight Concrete Blocks (100 PCF) U-Value Table¹

| Block Width: 10 Inches | | | Additional Insulation | | | | |
|---------------------------|------------|--------------------------------|-----------------------|-------|-------|-------------------|-------------------------|
| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
| | | | 0.75 | 1 | 2 | | |
| grouted | 0.45 | expanded ² | 0.19 | 0.16 | 0.10 | | 0.13 |
| grouted | 0.45 | extruded ³ | 0.16 | 0.13 | 0.079 | | |
| grouted | 0.45 | poly-isocyanurate ⁴ | 0.12 | 0.10 | 0.059 | | |
| grouted | 0.45 | fiberglass | | | | 0.081 | |
| empty | 0.37 | expanded | 0.17 | 0.15 | 0.097 | | 0.12 |
| empty | 0.37 | extruded | 0.14 | 0.12 | 0.076 | | |
| empty | 0.37 | poly-isocyanurate | 0.12 | 0.097 | 0.057 | | |
| empty | 0.37 | fiberglass | | | | 0.078 | |
| filled ⁵ | 0.14 | expanded | 0.099 | 0.091 | 0.068 | | 0.079 |
| filled | 0.14 | extruded | 0.089 | 0.080 | 0.057 | | |
| filled | 0.14 | poly-isocyanurate | 0.078 | 0.068 | 0.046 | | |
| filled | 0.14 | fiberglass | | | | 0.058 | |
| UFFI ⁶ | 0.13 | expanded | 0.092 | 0.085 | 0.065 | | 0.074 |
| UFFI | 0.13 | extruded | 0.084 | 0.076 | 0.055 | | |
| UFFI | 0.13 | poly-isocyanurate | 0.073 | 0.065 | 0.044 | | |
| UFFI | 0.13 | fiberglass | | | | 0.055 | |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

²Expanded is typically white “bead board” foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

Light Weight Concrete Blocks (100 PCF) U-Value Table¹

| Block Width: 8 Inches | | Additional Insulation | | |
|--------------------------|--|-----------------------|--|--|
|--------------------------|--|-----------------------|--|--|

MINNESOTA RULES 2003

853

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

| Core | Block Only | Type | Thickness (in.) | | | 2x4 studs R-11 | 2x2 furring 1.5 inch |
|---------------------|------------|--------------------------------|-----------------|-------|-------|-------------------|-------------------------|
| | | | 0.75 | 1 | 2 | | |
| gouted | 0.51 | expanded ² | 0.20 | 0.17 | 0.10 | | 0.13 |
| gouted | 0.51 | extruded ³ | 0.16 | 0.14 | 0.081 | | |
| gouted | 0.51 | poly-isocyanurate ⁴ | 0.13 | 0.10 | 0.060 | | |
| gouted | 0.51 | fiberglass | | | | 0.083 | |
| empty | 0.40 | expanded | 0.18 | 0.15 | 0.098 | | 0.16 |
| empty | 0.40 | extruded | 0.15 | 0.13 | 0.077 | | |
| empty | 0.40 | poly-isocyanurate | 0.12 | 0.098 | 0.058 | | |
| empty | 0.40 | fiberglass | | | | 0.091 | |
| filled ⁵ | 0.17 | expanded | 0.11 | 0.10 | 0.074 | | 0.086 |
| filled | 0.17 | extruded | 0.099 | 0.088 | 0.061 | | |
| filled | 0.17 | poly-isocyanurate | 0.085 | 0.074 | 0.048 | | |
| filled | 0.17 | fiberglass | | | | 0.062 | |
| UFFI ⁶ | 0.15 | expanded | 0.10 | 0.094 | 0.070 | | 0.081 |
| UFFI | 0.15 | extruded | 0.092 | 0.083 | 0.059 | | |
| UFFI | 0.15 | poly-isocyanurate | 0.080 | 0.070 | 0.047 | | |
| UFFI | 0.15 | fiberglass | | | | 0.059 | |

¹All U-values include air film coefficients and one-half inch gypsum board when insulation is present.

²Expanded is typically white "bead board" foam plastic.

³Extruded is typically colored R-5 per inch of foam plastic.

⁴Polyisocyanurate (iso board) is foam plastic, foil faced on both sides.

⁵Filled with vermiculite or EPS beam insulation.

⁶UFFI means filled with urea formaldehyde.

Subp. 6. **Metal buildings.** Thermal performance of envelope components of metal buildings with thermal insulation between purlins or girts must be determined by the effective assembly R-value method prescribed in this subpart.

A. The equation to determine thermal transmittance by effective assembly R-value thermal transmittance method is as follows:

$$U_o = 1/(R_1 + R_e)$$

Where:

R_1 = the R-values of series elements excluding the draped insulation and framing.

R_e = the effective assembly R-value from tables in item B or C. Interior air film coefficients are included in these table values.

B. The equivalent R-value of a purlin or girt system where the system is described in this item.

ASSEMBLY EFFECTIVE R-VALUES (R_e)

| Batt Insulation R-value | One Fastener Per Linear Foot of Purlin/Girt Purlin/Girt Spacing (Feet) | | | |
|-------------------------|--|-------|------|------|
| | 5 | 4 | 3 | 2 |
| R-38 | 11.61 | 10.18 | 8.45 | 6.30 |
| R-30 | 11.08 | 9.79 | 8.21 | 6.20 |

MINNESOTA RULES 2003

| | | | | |
|--|--|------|------|------|
| R-26 | 10.80 | 9.59 | 8.08 | 6.14 |
| R-22 | 10.06 | 9.04 | 7.73 | 5.99 |
| R-19 | 9.95 | 8.95 | 7.67 | 5.97 |
| Batt Insulation R-value | Two Fasteners Per Linear Foot of Purlin/Girt Purlin/Girt Spacing (Feet) | | | |
| | 5 | 4 | 3 | 2 |
| R-38 | 9.96 | 8.64 | 7.07 | 5.19 |
| R-30 | 9.56 | 8.36 | 6.91 | 5.12 |
| R-26 | 9.35 | 8.21 | 6.81 | 5.09 |
| R-22 | 8.80 | 7.80 | 6.56 | 4.98 |
| R-19 | 8.71 | 7.74 | 6.52 | 4.96 |

C. The assembly effective R-value (R_e) is defined in this item for purlin or girt insulation systems where purlin or girt spacing is five feet or greater. Foam blocks must be a minimum R-value of five, and a minimum of two pound density.

(1) For assemblies where the blanket insulation is draped over each purlin or girt and a foam block is installed between the purlin or girt and exterior panel, the R_e -values of this subitem apply.

| | INSULATION R-VALUE | | | |
|--------------------------|--------------------|------|------|------|
| | 10 | 11 | 13 | 19 |
| EFFECTIVE SYSTEM R-VALUE | 9.8 | 10.0 | 12.0 | 15.3 |

(2) For assemblies with a blanket total R-value of R-30, where a thicker layer is installed uncompressed between each purlin or girt and a thinner layer is draped over each purlin or girt, the R_e -values of this subitem apply.

(a) When a foam block is installed between the purlin or girt and exterior panel, the R_e -value is 24.5.

(b) When a foam block is not installed between the purlin or girt and exterior panel, the R_e -value is 17.4

(3) For assemblies where purlins or girts are completely filled with R-30, foam blocks of at least one-inch separate purlins or girts from the roof or wall sheet, and continuous insulation board covers the insulation and purlin or girt, the R_e -values of this subitem apply.

(a) Where the continuous insulation board is at least R-6, the R_e -value is R-31.4.

(b) Where the continuous insulation board is at least R-10, the R_e -value is R-43.2.

Subp. 7. **Metal stud walls.** The overall thermal transmittance of metal stud walls are provided in this subpart. The U-values given including studs and insulated cavity as well as siding, sheathing, gypsum board, and air films. The table U-values do not include effects of structural framing, which can substantially increase the U-value.

U-Values for Metal Stud Walls and Insulated Cavities

| Size of Studs | Stud Spacing | Cavity Insulation R-value | Insulated Cavity Equivalent | With Foam Plastic Insulation Sheathing | |
|---------------|--------------|---------------------------|-----------------------------|--|---|
| | | | | Extruded Polystyrene (in.) (R-5/in. minimum) | Polyisocyanurate (in.) (foil-backed foam board) |
| | | | | | |

MINNESOTA RULES 2003

855

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0500

| | | R-value | | | | | | |
|-----|-----|-----------------------------|-----|-------|-------|-------|-------|-------|
| | | | | 0.75 | 1 | 1.5 | 0.75 | 1 |
| | | Total Opaque Wall U-values* | | | | | | |
| 2x4 | 16" | 11 | 5.5 | 0.086 | 0.077 | 0.065 | 0.075 | 0.066 |
| 2x4 | 16" | 13 | 6.0 | 0.082 | 0.075 | 0.063 | 0.072 | 0.064 |
| 2x4 | 16" | 15 | 6.4 | 0.080 | 0.072 | 0.061 | 0.070 | 0.062 |
| 2x4 | 24" | 11 | 6.6 | 0.078 | 0.071 | 0.061 | 0.069 | 0.061 |
| 2x4 | 24" | 13 | 7.2 | 0.075 | 0.068 | 0.058 | 0.067 | 0.059 |
| 2x4 | 24" | 15 | 7.8 | 0.072 | 0.066 | 0.056 | 0.064 | 0.064 |
| 2x6 | 16" | 19 | 7.1 | 0.075 | 0.069 | 0.059 | 0.067 | 0.060 |
| 2x6 | 16" | 21 | 7.4 | 0.074 | 0.067 | 0.058 | 0.066 | 0.059 |
| 2x6 | 24" | 19 | 8.6 | 0.068 | 0.062 | 0.054 | 0.061 | 0.055 |
| 2x6 | 24" | 21 | 9.0 | 0.066 | 0.061 | 0.053 | 0.059 | 0.059 |
| 2x8 | 16" | 25 | 7.8 | 0.072 | 0.066 | 0.056 | 0.064 | 0.057 |
| 2x8 | 24" | 25 | 9.6 | 0.063 | 0.059 | 0.051 | 0.057 | 0.052 |

*This U-value includes studs and insulated cavity, as well as siding, sheathing, gypsum board, and air film. It does not include structural framing.

Subp. 8. **Zone method.** For assemblies with metal components that are not described in subpart 6 or 7, the zone method must be used. The zone method is a procedure in which the thermal transmittance of a surface is computed by dividing the surface into its highly conductive and remaining areas. The highly conductive area is a function of the width or diameter of the metal heat path terminal and the distance from the panel surface to the metal. The respective thermal transmittance of the two areas are separately computed, combined, and then divided by the total cross-sectional area.

The equation for zone method thermal transmittance is as follows:

$$U = (U_1A_1 + U_2A_2)/A_0$$

Where:

For the highly conductive area:

A_1 = the highly conductive area.

U_1 = the thermal transmittance of the highly conductive area.

For the remainder of the area:

A_2 = the remainder of the area.

U_2 = the thermal transmittance of the remaining area.

A_0 (cross-sectional area of the element) = $A_1 + A_2$.

The equation for areas is as follows:

$$A_1 = m + 2d, A_2 = A_0 - A_1$$

Where:

m = width or diameter of the metal heat path terminal.

d = distance from panel surface to metal.

Subp. 9. **Thermal measurement method.**

A. The overall thermal transmittance value of a building assembly determined by testing must be tested by either ASTM C236 or ASTM C976 by a laboratory meeting the qualities in item B.

B. Approved laboratory means any testing facility, including a facility owned or operated by a manufacturer, that has been accredited by one or more of the following agencies to perform the required test:

MINNESOTA RULES 2003

7678.0500 ENERGY CODE; EFFICIENCIES, CALCULATIONS

856

(1) United States Department of Commerce, National Voluntary Laboratory Accreditation Program;

(2) American Association for Laboratory Accreditation, Gaithersburg, Maryland; or

(3) Standards Council of Canada, Ottawa, Ontario, Canada.

EXCEPTION: In the event that an approved laboratory program is temporarily delayed or is not capable of being accredited to perform a test or tests, a testing laboratory possessing the appropriate equipment, facilities, and qualified personnel to perform the required testing is an approved laboratory.

C. Product samples must be production line material or representative material as purchased by the consumer or contractor. If the assembly is too large to be tested at one time in its entirety, then either a representative portion must be tested or different portions must be tested separately and a weighted average determined. To be representative, the portion tested must include edges of panels, joints with other panels, typical framing percentages, and thermal short circuits.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0600 FENESTRATION PRODUCTS.

Subpart 1. **Labeling.** All windows must be labeled with their overall assembly U-value according to this part. Labels must not be removed until after inspection of installation.

Subp. 2. **Air infiltration.** Fenestration products must have air infiltration rates not exceeding those shown in this subpart. The manufacturer must test for infiltration rates in accordance with ASTM E283-91, and window infiltration rates in accordance with applicable industry standards. A labeled statement from the manufacturer that the product meets or exceeds the requirements of the Model Energy Code shall be deemed to comply with these requirements.

ALLOWABLE AIR INFILTRATION RATE

| | |
|-----------------------------|--|
| Operable windows | 0.34 cfm per lineal foot of operable sash crack or 0.30 cfm per square foot of window area |
| Residential doors, swinging | 0.5 cfm per square foot of door area |
| Residential doors, swinging | 0.37 cfm per square foot of door area |
| Nonresidential doors | 1.25 cfm per square foot of door area |

Subp. 3. **Thermal transmittance.** Thermal transmittance of windows, doors, and skylight elements must be determined in accordance with item A or B.

A. Thermal performance (U-values) of fenestration products (windows, doors, and skylights) must be determined in accordance with the National Fenestration Rating Council (NFRC) standard 100-91, 100-97, or equivalent by an accredited, independent laboratory, and labeled and certified by the manufacturer.

B. When a manufacturer has not determined product U-value according to NFRC standards for a particular product line, the U-value shall be determined by assigning products a default U-value from the U-value default table. Product features must be verifiable for the product to qualify for the default value associated with those features. Where the existence of a particular feature cannot be determined with

MINNESOTA RULES 2003

857

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0600

reasonable certainty, the product must not receive credit for that feature. Where a composite of materials from two different product types are used, the product U-value must be the high U-value.

(1) The U-value default table for windows, glass doors, and skylights is as follows:

| Frame/Glazing Features | Double Pane | Double Pane w/ Low-E Permanent Label on Glass | Triple Pane |
|---------------------------------|-------------|---|----------------|
| | U-value | U-value | U-value |
| Metal With Thermal Break | | | |
| Operable | 0.67 | 0.62 | 0.54 |
| Fixed | 0.63 | 0.57 | 0.47 |
| Glass door | 0.66 | 0.60 | 0.50 |
| Skylight | 1.13 | 1.06 | 0.93 |
| Metal-Clad Wood | | | |
| Operable | 0.60 | 0.56 | 0.46 |
| Fixed | 0.58 | 0.52 | 0.41 |
| Glass door | 0.57 | 0.52 | 0.43 |
| Skylight | 0.88 | 0.82 | 0.71 |
| Wood/Vinyl | | | |
| Operable | 0.56 | 0.52 | 0.43 |
| Fixed | 0.57 | 0.52 | 0.41 |
| Glass door | 0.56 | 0.51 | 0.42 |
| Skylight | 0.85 | 0.79 | 0.67 |
| Glass Block Assemblies | 0.60 | | |

(2) The U-value default table for nonglazed doors is as follows:

| Steel Doors | U-Value | |
|------------------------------|---------------|------------|
| Without foam core | 0.60 | |
| With foam core | 0.35 | |
| | | |
| Wood Doors | U-Value | |
| | Without Storm | With Storm |
| Panel with 7/16 inch panels | 0.54 | 0.36 |
| Panel with 1-1/8 inch panels | 0.39 | 0.28 |
| Solid core flush | 0.40 | 0.26 |

Subp. 4. Solar heat gain coefficients. Solar heat gain coefficients of windows, glazed doors, and skylight elements must be determined according to this subpart.

A. The solar heat gain coefficient (SHGC) of glazed fenestration products (windows, glazed doors, and skylights) shall be determined according to the National Fenestration Rating Council (NFRC) standards by an accredited, independent laboratory, and labeled and certified by the manufacturer.

B. When a manufacturer has not determined product SHGC according to NFRC standards for a particular product line, the SHGC shall be determined by assigning such products a default SHGC from the SHGC default table. Product

MINNESOTA RULES 2003

features must be verifiable for the product to qualify for the default value associated with those features. Where the existence of a particular feature cannot be determined with reasonable certainty, the product must not receive credit for that feature. Where a composite of materials from two different product types are used, the product shall be assigned the higher value.

The SHGC default table for windows, glazed doors, and skylights is as follows:

| PRODUCT DESCRIPTION | | SINGLE GLAZED | | | |
|---------------------|-------|---------------|-------|------|--|
| Metal-Framed: | Clear | Bronze | Green | Gray | |
| Operable | 0.75 | 0.64 | 0.62 | 0.61 | |
| Fixed | 0.78 | 0.67 | 0.65 | 0.64 | |
| | | | | | |
| Nonmetal Frames: | | | | | |
| Operable | 0.63 | 0.54 | 0.53 | 0.52 | |
| Fixed | 0.75 | 0.64 | 0.62 | 0.61 | |
| | | | | | |
| PRODUCT DESCRIPTION | | DOUBLE GLAZED | | | |
| Metal-Framed: | Clear | Bronze | Green | Gray | |
| Operable | 0.66 | 0.55 | 0.53 | 0.52 | |
| Fixed | 0.68 | 0.57 | 0.55 | 0.54 | |
| | | | | | |
| Nonmetal Frames: | | | | | |
| Operable | 0.55 | 0.46 | 0.45 | 0.44 | |
| Fixed | 0.66 | 0.54 | 0.53 | 0.52 | |

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0700 MECHANICAL EQUIPMENT EFFICIENCY REQUIREMENTS.

Subpart 1. **HVAC equipment performance requirements.** HVAC equipment must meet the minimum efficiency requirements specified in this part.

A. Standards and definitions for HVAC equipment include coefficient of performance; package terminal air conditioner; package terminal heat pump; room air conditioner; unitary cooling and heating equipment; unitary heat pump; water chilling package of absorption; water chilling package, centrifugal or rotary; and water chilling package, reciprocating, are located or referenced in Code of Federal Regulations, title 10, parts 430 and 435.

B. Omissions of minimum performance requirements for equipment not listed in this part does not preclude use of such equipment.

C. When multiple rating conditions or performance requirements are provided, the equipment must satisfy all stated requirements.

Subp. 2. **Air cooled, electrically operated equipment.** Unitary conditioners, heat pumps, and condensing units air cooled, electrically operated must meet the requirements of this subpart. Deduct 0.2 from required EER and IPLV for units that have a heating section. IPLV's are applicable to equipment with capacity modulation. Minimum efficiencies have not been determined for condensing only units less than 135,000 Btu/h.

**UNITARY AIR CONDITIONERS AND AIR-COOLED,
ELECTRICALLY OPERATED HEAT PUMPS**

| EQUIPMENT CATEGORY | EQUIPMENT SIZES AND MODE | RATING CONDITION | EFFICIENCY |
|--------------------|---|------------------|------------|
| Single Package | <65,000 Btu/h Cooling Capacity Cooling Mode | Seasonal Rating | 9.7 SEER |

MINNESOTA RULES 2003

859

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0700

| | | | |
|---|--|---|-------------------------|
| Split System | <65,000 Btu/h Cooling Capacity Cooling Mode | | 10.0 SEER |
| Split System and Single Package | ≥65,000 and <135,000 Btu/h Cooling Mode | Standard Rating (95°F db) Integrated Part Load Value (80°F db) | 8.9 EER 8.3 IPLV |
| Heat Pumps - Cooling Mode | | | |
| Split System and Single Package | >135,000 Btu/h and <240,000 Btu/h | | 8.5 EER 7.5 IPLV |
| Phase Split System and Single Package | >240,000 Btu/h and <760,000 Btu/h | | 8.5 EER 7.5 IPLV |
| Phase Split System and Single Package | >760,000 Btu/h | | 8.2 EER 7.5 IPLV |
| Heat Pumps - Heating Mode | | | |
| Split System | <65,000 Btu/h Cooling Capacity Heating Mode | Seasonal Rating | 6.8 HSPF |
| Single Package | | | 6.6 HSPF |
| Split System and Single Package | ≥65,000 and <135,000 Btu/h Cooling Capacity Heating Mode | High Temperature Rating (47°F db/ 43°F wb) Low Temperature Rating (17°F db/ 15°F wb) | 3.0 COP 2.0 COP |
| Split System and Single Package | ≥135,000 and <240,000 Btu/h Cooling Capacity Heating Mode | High Temperature Rating (47°F db/ 43°F wb) Low Temperature Rating (17°F db/ 15°F wb) | 2.9 COP 2.0 COP |
| Split System and Single Package | >240,000 and <760,000 Btu/h | High Temperature Rating (47°F db/ 43°F wb) Low Temperature Rating (17°F db/ 15°F wb) | 2.9 COP 2.0 COP |

MINNESOTA RULES 2003

7678.0700 ENERGY CODE; EFFICIENCIES, CALCULATIONS

860

| | | | |
|---------------------------------------|----------------|---|------------------------|
| Split System and Single Package | >760,000 Btu/h | High Temperature Rating (47°F db/ 43°F wb) Low Temperature Rating (17°F db/ 15°F wb) | 2.9 COP 2.0 COP |
| Condensing Units | ≥135,000 Btu/h | | 11.0 IPLV 9.9 EER |

Subp. 3. **Electrically operated, water and evaporatively cooled equipment.** Unitary air conditioners, heat pumps, and condensing units electrically operated, evaporatively cooled must meet the requirements of this subpart. Deduct 0.2 from required EER and IPLV for units that have a heating section. IPLV's are applicable to equipment with capacity modulation. Minimum efficiencies have not been determined for condensing only units less than 135,000 Btu/h.

ELECTRICALLY OPERATED, EVAPORATIVELY COOLED EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES AND MODE | RATING CONDITION | EFFICIENCY |
|---------------------------------------|--|---|-----------------------|
| Split System and Single Package | All | For EER: Indoor Temperature (80°F db/67°F wb) Outdoor Temperature (95°F db/75°F wb) For IPLV: (80°F db/67°F wb) | |
| Split System and Single Package | <65,000 Btu/h Cooling Capacity | | 9.3 EER 8.4 IPLV |
| Split System and Single Package | <135,000 Btu/h Cooling Capacity | | 10.5 EER 9.7 IPLV |
| Split System and Single Package | ≥135,000 and <240,000 Btu/h Cooling Capacity | | 9.6 EER 9.0 IPLV |
| Split System and Single Package | ≥240,000 and <760,000 Btu/h Cooling Capacity | | 9.6 EER 9.0 IPLV |
| Split System and Single Package | >760,000 Btu/h | | 9.6 EER 9.0 IPLV |
| Condensing Units | ≥135,000 Btu/h | | 12.9 EER 12.9 IPLV |

Subp. 4. **Water-cooled equipment.** Water-cooled air conditioners, heat pumps, and condensing units must meet the requirements of this subpart. Minnesota Statutes, section 103G.271, subdivision 5, prohibits once-through systems.

MINNESOTA RULES 2003

861

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0700

WATER-COOLED EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES AND MODE | RATING CONDITION | EFFICIENCY |
|-------------------------------|---|---|------------|
| Water Source Heat Pumps | <65,000 Btu/h Cooling Capacity | Standard Rating Indoor Air (80°F db/65°F wb) and Entering Water (85°F) | 9.3 EER |
| | | Low Temperature Rating Indoor Air (80°F db/67°F wb) and Entering Water (75°F) | 10.2 EER |
| | ≥65,000 and <135,000 Btu/h Cooling Capacity | Standard Rating Indoor Air (80°F db/67°F wb) and Entering Water (85°F) | 10.5 EER |
| Groundwater Cooled Heat Pumps | <135,000 Btu/h Cooling Capacity | Entering Water (75°F) | 11.00 EER |
| | | Standard Rating Entering Water (70°F) | 11.0 EER |
| Groundwater Cooled Heat Pumps | <135,000 Btu/h Cooling Capacity | Low Temperature Rating Entering Water (50°F) | 11.5 EER |

Subp. 5. **Packaged terminal equipment.** Packaged terminal air conditioners and heat pumps air cooled, electrically operated must meet the requirements of this subpart. Equipment must comply with all efficiencies when multiple efficiencies are indicated. “Cap” means the rated capacity in Btu/h. If the equipment capacity is less than 7,000 Btu/h, use 7,000 Btu/h in the calculation. If the equipment capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculation.

PACKAGED TERMINAL EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES AND MODE | RATING CONDITION | EFFICIENCY |
|--------------------------|-----------------------------|----------------------------------|--------------------------------|
| PTAC AND PTAC Heat Pumps | All Capacities Cooling Mode | Standard Rating (95°F db) | 10.0 - (0.16 x Cap./1,000) EER |
| | | Low Temperature Rating (82°F db) | 12.2 - (0.20 x Cap./1,000) EER |

MINNESOTA RULES 2003

| | | | |
|-----------------|-----------------------------|-----------------------------------|--------------------------------|
| PTAC Heat Pumps | All Capacities Heating Mode | Standard Rating (47°F db/43°F wb) | 2.9 - (0.026 x Cap./1,000 COP) |
|-----------------|-----------------------------|-----------------------------------|--------------------------------|

Subp. 6. **Room equipment.** Room air conditioners and room air conditioner heat pumps must meet the requirements of this subpart. Equipment must comply with all efficiencies when multiple efficiencies are indicated.

ROOM EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES & MODE | EFFICIENCY |
|--|---------------------------|------------|
| Without Reverse Cycle and with Louvered Sides | <6,000 Btu/h | 8.0 EER |
| | ≥6,000 and <8,000 Btu/h | 8.5 EER |
| | ≥8,000 and <14,000 Btu/h | 9.0 EER |
| | ≥14,000 and <20,000 Btu/h | 8.8 EER |
| | ≥20,000 Btu/h | 8.2 EER |
| Without Reverse Cycle and without Louvered Sides | <6,000 Btu/h | 8.0 EER |
| | ≥6,000 and <20,000 Btu/h | 8.5 EER |
| | ≥20,000 Btu/h | 8.2 EER |
| With Reverse Cycle and With Louvered Sides - All Capacities | | 8.5 EER |
| With Reverse Cycle and Without Louvered Sides - All Capacities | | 8.0 EER |

Subp. 7. **Water source equipment.** Water source, groundwater source, and ground source heat pumps electrically operated must meet the requirements of this subpart. Minnesota Statutes, section 103G.271, subdivision 5, prohibits once-through systems.

WATER SOURCE EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES AND MODE | RATING CONDITION | EFFICIENCY |
|-------------------------------|--------------------------|---|------------|
| Water Source | <135,000 Btu/h | Standard Rating Entering Water (70°F) | 3.8 COP |
| | | Entering Water (75°F) | 3.9 COP |
| Groundwater Source Heat Pumps | <135,000 Btu/h | High Temperature Rating Entering Water (70°F) | 3.4 COP |
| | | Low Temperature Rating Entering Water (50°F) | 3.0 COP |

MINNESOTA RULES 2003

863

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0700

| | | | |
|--------------------------|----------------|--|----------|
| Ground Source Heat Pumps | <135,000 Btu/h | High Temperature Rating Entering Water (41°) | 2.70 COP |
| | | Low Temperature Rating Entering Water (32°) | 2.50 COP |

Subp. 8. **Gas-fired and oil-fired equipment.** Gas-fired and oil-fired boilers, furnaces, and unit heaters and combination furnace/air conditioner units must meet the requirements of this subpart. Minimum and maximum ratings must be as provided for and allowed by the equipment controls.

GAS-FIRED AND OIL-FIRED EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES AND MODE | RATING CONDITION | MINIMUM EFFICIENCY |
|-------------------------|--------------------------|---|---------------------|
| Gas-fired boilers | <300,000 Btu/h | Hot water | 80% AFUE |
| | | Steam | 75% AFUE |
| | >300,000 | Both maximum and minimum rated capacity | 80% Ec* or 80% Et** |
| Gas-fired furnaces | <225,000 Btu/h | Seasonal rating | 78% AFUE |
| | >225,000 Btu/h | Maximum rated capacity | 80% Et** |
| | | Minimum rated capacity | 78% Et |
| Gas-fired duct furnaces | All sizes | Maximum rated capacity | 78% Et |
| | | Minimum rated capacity | 75% Et |
| Gas-fired unit heaters | All sizes | Maximum rated capacity | 78% Et |
| | | Minimum rated capacity | 74% Et |
| Oil-fired furnaces | <225,000 Btu/h | Seasonal rating | 78% AFUE |
| | >225,000 Btu/h | Both maximum and minimum rated capacity | 81% Et** |
| Oil-fired boilers | <300,000 Btu/h | Seasonal rating | 80% AFUE |
| | >300,000 Btu/h | Both maximum and minimum rated capacity | 83% Ec* |

MINNESOTA RULES 2003

| | | | |
|------------------------------------|----------------|---|--------|
| Oil-fired boilers (residual) | >300,000 Btu/h | Both maximum and minimum rated capacity | 83% Ec |
| Oil-fired unit heaters | All sizes | Both maximum and minimum rated capacity | 81% Et |

*Ec = Efficiency, combustion

**Et = Efficiency, thermal

Subp. 9. **Mobile home equipment.** Mobile home furnaces, steam boilers, and direct heating equipment must meet the requirements of this subpart.

MOBILE HOME EQUIPMENT

| EQUIPMENT | EQUIPMENT SIZES | EFFICIENCY (AFUE) |
|--|---------------------------|----------------------|
| Mobile Home Furnaces | | 75 percent |
| Gas Steam Boilers | | 75 percent |
| Gas Fueled Direct Heating Equipment Vented Wall Furnaces | <42,000 Btu/h | 73 percent |
| Fan Type | ≥42,000 Btu/h | 74 percent |
| Vented Wall Furnaces | <10,000 Btu/h | 59 percent |
| | ≥10,000 and <12,000 Btu/h | 60 percent |
| Gravity Type | ≥12,000 and <15,000 Btu/h | 61 percent |
| | ≥15,000 and <19,000 Btu/h | 62 percent |
| | ≥19,000 and <27,000 Btu/h | 63 percent |
| | ≥27,000 and <46,000 Btu/h | 64 percent |
| | ≥46,000 Btu/h | 65 percent |
| Vented Floor Furnaces | <37,000 Btu/h | 56 percent |
| | ≥37,000 Btu/h | 57 percent |
| Vented Room Heaters | <18,000 Btu/h | 57 percent |
| | ≥18,000 and <20,000 Btu/h | 58 percent |
| | ≥20,000 and <27,000 Btu/h | 63 percent |
| | ≥27,000 and <46,000 Btu/h | 64 percent |
| | ≥46,000 Btu/h | 65 percent |

Subp. 10. Water chilling packages.

A. Double effect, heat operated water chilling packages must be used in lieu of single effect equipment.

EXCEPTION: Single effect equipment may be used when all energy input is from low temperature waste heat or renewable energy sources.

B. Water chilling packages, water and air cooled, electrically operated must meet the requirements of this subpart.

MINNESOTA RULES 2003

865

ENERGY CODE; EFFICIENCIES, CALCULATIONS 7678.0800

ELECTRICALLY OPERATED WATER CHILLER PACKAGES

| WATER-COOLED | CFC | NON-CFC |
|----------------------------------|-------------|-------------|
| Centrifugal | 0.63 KW/Ton | 0.73 KW/Ton |
| Helical-rotary (screw) | 0.75 KW/Ton | 0.80 KW/Ton |
| Reciprocating or scroll | 0.93 KW/Ton | |
| AIR-COOLED (any type) | | |
| ≥150 Ton | 1.41 KW/Ton | |
| <150 Ton | 1.30 KW/Ton | |

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0800 SERVICE WATER HEATING EQUIPMENT EFFICIENCY REQUIREMENTS.

Subpart 1. **Scope.** Service water heating equipment must meet the minimum efficiency requirements in this part.

Subp. 2. **Standards.** Standards for service water heating equipment are located in Code of Federal Regulations, title 10, parts 430 and 435.

Subp. 3. **Efficiency.** Efficiency requirements for water heaters regulated by the National Appliance Energy Conservation Act.

EFFICIENCY REQUIREMENTS FOR WATER HEATERS REGULATED BY THE NATIONAL APPLIANCE ENERGY CONSERVATION ACT

| Fuel Type (Size) | Energy Factor |
|------------------------------------|------------------------------------|
| Storage gas (<75,000 Btu/h) | 0.62 - (0.0019 x V _v) |
| Instantaneous Gas (<200,000 Btu/h) | 0.62 - (0.0019 x V _v) |
| Storage oil (<105,000 Btu/h) | 0.59 - (0.0019 x V _v) |
| Instantaneous oil (<210,000 Btu/h) | 0.59 - (0.0019 x V _v) |
| Electric (<12 kw) | 0.93 - (0.00132 x V _v) |
| Pool heater (all sizes) | Thermal efficiency > 78 percent |

Where: V_v = rated storage volume in gallons.

Subp. 4. **Other water heaters.** Efficiency requirements for all other water heaters.

EFFICIENCY REQUIREMENTS FOR ALL OTHER WATER HEATERS

| Fuel Type | Input Rating or Volume | Input to Volume Ratio (Btu/gal) | Minimum Thermal Efficiency | Maximum Standby Loss (% hour) |
|-----------|------------------------|---------------------------------|----------------------------|-------------------------------|
| Electric | >12 KW | | | 0.30 + 27 ÷ V _t |
| Gas/Oil | ≤155,000 Btu/h | | 78 percent | 1.30 + 114 ÷ V _t |

MINNESOTA RULES 2003

7678.0800 ENERGY CODE; EFFICIENCIES, CALCULATIONS

866

| | | | | |
|-----------------------|---------------|-----------|------------|---|
| Gas/Oil | | | | $1.3 + 95 \div V_t$ |
| Gas/Oil | ≥ 10 gal | $> 4,000$ | 80 percent | $2.3 + 67 \div V_t$ |
| Gas/Oil | < 10 gal | $< 4,000$ | 78 percent | |
| Gas/Oil | All | $> 4,000$ | 77 percent | $2.3 + 67 \div V_t$ |
| Unfired storage tanks | All | | | ≤ 6.5 Btu/hr/sq. ft. based on 80°F water-to-air temperature difference |

Where: V_t = the measured storage volume in gallons.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*

7678.0900 EFFECTIVE DATE.

This chapter is effective July 20, 1999.

Statutory Authority: *MS s 216C.19*

History: *23 SR 145*