

**1305.0402 SECTION 402, COVERED MALL AND OPEN MALL BUILDINGS.**

Subpart 1. [Repealed, 44 SR 609]

Subp. 2. [Repealed, 32 SR 7]

Subp. 3. **IBC section 402.7.2.** IBC section 402.7.2 is amended to read as follows:

**402.7.2 Smoke control.** Where a covered mall building contains an atrium, a smoke control system shall be provided in accordance with Section 404.5.

**Exception:** Smoke control is not required in covered mall buildings where an atrium connects only two stories.

Covered mall buildings exceeding 50,000 square feet (4645 m<sup>2</sup>) in floor area, excluding anchor buildings, not provided with an approved smoke control system, shall be provided with a post-fire smoke exhaust system in accordance with Minnesota Rules, part 1305.0919.

**Statutory Authority:** *MS s 16B.37; 16B.59 to 16B.76; 326B.02; 326B.101 to 326B.194*

**History:** *27 SR 1474; 32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64; 39 SR 1605; 44 SR 609*

**Published Electronically:** *March 31, 2020*