

**1305.0403 SECTION 403, HIGH-RISE BUILDINGS.**

Subpart 1. **IBC Section 403.3.2.** IBC Section 403.3.2 is deleted in its entirety.

Subp. 2. **IBC Section 403.** IBC Section 403 is amended by adding a section to read as follows:

**403.15 Post-fire smoke exhaust system.** A post-fire smoke exhaust system in compliance with IBC Section 913 shall be provided for high-rise buildings.

**Statutory Authority:** *MS s 16B.37; 16B.59 to 16B.76; 326B.101 to 326B.194*

**History:** *27 SR 1474; 32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64*

**Published Electronically:** *February 23, 2009*