

1305.0403 SECTION 403, HIGH-RISE BUILDINGS.

Subpart 1. **IBC section 403.2.1.2.** IBC section 403.2.1.2 is deleted in its entirety.

Subp. 2. [Repealed, 39 SR 1605]

Subp. 3. **IBC section 403.4.8.3.** IBC section 403.4.8.3 is amended to read as follows:

403.4.8.3 Standby power loads. The following are classified as standby power loads:

1. power and lighting for the fire command center required by Section 403.4.6;
2. ventilation and automatic fire detection equipment for smokeproof enclosures; and
3. passenger elevators serving occupied floors more than 75 feet (22, 860 mm) above the lowest level of fire department vehicle access.

Statutory Authority: *MS s 16B.37; 16B.59 to 16B.76; 326B.02; 326B.101 to 326B.194*

History: *27 SR 1474; 32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64; 39 SR 1605; 44 SR 609*

Published Electronically: *March 31, 2020*