

1305.0407 SECTION 407, GROUP I-2.

IBC Section 407.2.1 is amended to read as follows:

407.2.1 Spaces of unlimited area. In an I-2 occupancy, spaces constructed as required for corridors shall be permitted to be open to a corridor, only where all the following criteria are met:

1. The spaces are not occupied for patient sleeping rooms, treatment rooms, hazardous or incidental use areas as defined in Section 508.2.
2. The open space is protected by an automatic fire detection system installed in accordance with Section 907.
3. The corridors onto which the spaces open, in the same smoke compartment, are protected by an automatic fire detection system installed in accordance with Section 907, or the smoke compartment in which the spaces are located is equipped throughout with quick response sprinklers in accordance with Section 903.3.2.
4. The space is arranged so as not to obstruct access to the required exits.

Statutory Authority: *MS s 16B.37; 16B.59 to 16B.76; 326B.101 to 326B.194*

History: *27 SR 1474; 32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64*

Published Electronically: *February 23, 2009*