

1305.0912 [F] SECTION 912, FIRE DEPARTMENT CONNECTIONS.

IBC [F] Section 912.2 is amended by adding a subsection to read:

912.2.3 Connection height. Newly installed fire department connections shall be located not less than 18 inches (457 mm) and not more than 4 feet (1.2 m) above the level of the adjacent grade or access level.

Statutory Authority: *MS s 16B.37; 16B.59 to 16B.76; 326B.101 to 326B.194*

History: *27 SR 1474; 32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64*

Published Electronically: *February 23, 2009*