

1311.0405 SECTION 405, SHAFT ENCLOSURES.

Subpart 1. **Section 405.1.** GREB Section 405.1 is amended to read as follows:

405.1 In any work area, newly constructed vertical openings through a floor ceiling assembly shall comply with the requirements of the Minnesota State Building Code.

Subp. 2. **Section 405.2.** GREB Section 405.2 is amended to read as follows:

405.2 In any work area, all existing interior vertical openings through a floor ceiling assembly shall be enclosed with approved assemblies having a fire-resistance rating of not less than one hour with approved opening protection.

(The exceptions are included and remain unchanged.)

Subp. 3. **Sections 405.3, 405.4, and 405.5.** GREB Sections 405.3, 405.4, and 405.5 are amended to delete the reference to "(Supplemental requirements)."

Statutory Authority: *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

History: *27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4*

Published Electronically: *February 23, 2009*