

1311.0413 SECTION 413, OTHER SAFETY FEATURES.

Subpart 1. **Section 413.2.3.** GREB Section 413.2.3, the Exceptions are amended to read as follows:

Exceptions:

1. If the existing load is less than 10 kva as computed in accordance with the Minnesota Electrical Code, an existing 60 ampere three-wire service shall be permitted.
2. 30-ampere and larger two- or three-wire feeders supplying dwelling units shall be permitted where the feeders are adequate for the load served as computed in the Minnesota Electrical Code.

Subp. 2. **Section 413.2.4.3.** GREB Section 413.2.4.3 is amended as follows:

413.2.4.3 Laundry areas shall have a minimum of one grounded-type outlet or a receptacle outlet protected with a ground-fault circuit-interrupter located near each piece of laundry equipment and at least one lighting outlet.

Subp. 3. **Section 413.2.4.5.** GREB Section 413.2.4.5 is amended as follows:

413.2.4.5 At least one lighting outlet shall be provided in every kitchen, toilet room, bathroom, hallway, stairway, attached garage, and detached garage with electric power.

Subp. 4. **Section 413.2.4.8.** GREB Section 413.2.4 is amended by adding the following subsection:

413.2.4.8 Each toilet room and bathroom shall have a receptacle outlet provided with ground-fault circuit-interrupter protection.

Statutory Authority: *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

History: *27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4*

Published Electronically: *February 23, 2009*