

1311.1012 SECTION 1012, CHANGE OF OCCUPANCY CLASSIFICATION.

Section 1012.2.1 Fire sprinkler system. IEBC section 1012.2.1 is amended to read as follows:

1012.2.1 Fire sprinkler system. Where a change in occupancy classification occurs that requires an automatic fire sprinkler system to be provided based on the new occupancy in accordance with Minnesota Rules, chapter 1305, such system shall be provided throughout the area where the change of occupancy occurs.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106*

History: *39 SR 95*

Published Electronically: *January 26, 2015*