

1311.1402 SECTION 1402, REQUIREMENTS.

Subpart 1. **Section 1402.3 Wind loads.** IEBC section 1402.3 is amended to read as follows:

1402.3 Wind loads. Buildings shall comply with International Building Code wind provisions, as applicable.

Exceptions:

1. Detached one- and two-family dwellings and Group U occupancies where wind loads at the new location are not higher than those at the previous location.
2. Structural elements whose demand-capacity ratio is not increased to more than 110 percent. For purposes of this exception, comparisons of demand-capacity ratios and calculation of design lateral loads, forces, and capacities shall account for the cumulative effects of additions and alterations since original construction.

Subp. 2. **Section 1402.5 Snow loads.** IEBC section 1402.5 is amended to read as follows:

1402.5 Snow loads. Structures shall comply with International Building Code snow loads as applicable where snow loads at the new location are higher than those at the previous location.

Exception: Structural elements whose demand-capacity ratio is not increased to more than 105 percent. For purposes of this exception, comparisons of demand-capacity ratios and calculation of design gravity loads, forces, and capacities shall account for the cumulative effects of additions and alterations since original construction.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106*

History: *39 SR 95; 44 SR 487*

Published Electronically: *March 31, 2020*