

1323.0404 SECTION C404, SERVICE WATER HEATING (MANDATORY).

IECC section C404.9.3 is amended to read as follows:

C404.9.3 Covers. Heated pools and inground, permanently installed spas shall be provided with a vapor-retardant cover. Covers for heated swimming pools shall comply with Minnesota Rules, part 4717.1575, the Minnesota Department of Health pool cover safety standard. Pools heated to more than 90°F shall have a pool cover with a minimum insulation value of R-12.

Exception: A vapor-retardant cover is not required for pools deriving over 75 percent of the energy for heating from site-recovered energy, such as a heat pump or solar energy source computed over an operating season.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106*

History: *39 SR 1616; 44 SR 763*

Published Electronically: *April 1, 2020*