

1323.0643 [Repealed, 39 SR 1616]

1323.0643 SECTION 6.4.3, CONTROLS AND DIAGNOSTICS.

Subpart 1. **ASHRAE 90.1 section 6.4.3.4.2 Ventilation system control.** ASHRAE 90.1 section 6.4.3.4.2 is amended by modifying the exception 1 to read as follows:

1. [Reserved].

Subp. 2. **ASHRAE 90.1 section 6.4.3.4.2 Ventilation system control.** ASHRAE 90.1 section 6.4.3.4.2 is amended by modifying the exception 2 to read as follows:

2. Nonmotorized dampers are acceptable in systems with a design outdoor air intake, relief, or exhaust capacity of 300 cfm or less. Nonmotorized dampers for outdoor air intakes must be protected from direct exposure to wind.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106*

History: *47 SR 983*

Published Electronically: *December 7, 2023*