

1323.0741 SECTION 7.4.1, LOAD CALCULATIONS.

ASHRAE Standard 90.1, Section 7.4.1, is amended to read:

7.4.1 Load calculations. Service water heating system design loads for the purpose of sizing systems and equipment shall be determined in accordance with the procedures described in the ASHRAE Handbook-HVAC Applications or an equivalent computation procedure.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106; 326B.13*

History: *33 SR 1473*

Published Electronically: *June 17, 2009*