

**1323.0753 SECTION 7.5.3, BUILDINGS WITH HIGH-CAPACITY SERVICE WATER HEATING SYSTEMS.**

**ASHRAE 90.1 section 7.5.3.** ASHRAE 90.1 section 7.5.3 is amended by modifying exception 1 to read as follows:

1. Where at least 50 percent of the annual service water-heating requirement is provided by site-solar energy or site-recovered energy. The site-solar energy or site-recovered energy used for compliance with this exception cannot be used for compliance with any other section of this standard.

**Statutory Authority:** *MS s 326B.02; 326B.101; 326B.106*

**History:** *47 SR 983*

**Published Electronically:** *December 7, 2023*