

1335.2500 FLOODPROOFING REGULATIONS, SECTION 1302.2.2.

FPR section 1302.2.2 is amended to read as follows:

Where the state of dryness of a space is dependent on a sump pump system, or where the stability of a structure during a flood event depends on the relief of uplift pressures on building components, all interior storm water drainage or seepage, appliance drainage, and underslab drain tile systems shall be directly connected to a sump (pump) and discharged at an elevation at least three feet above the RFD.

Statutory Authority: *MS s 104.05*

Published Electronically: *July 30, 2007*