

1335.2500 FLOODPROOFING REGULATIONS, SECTION 1302.2.2.

FPR section 1302.2.2 is amended to read as follows:

Where the state of dryness of a space is dependent on a sump pump system, or where the stability of a structure during a flood event depends on the relief of uplift pressures on building components, all interior stormwater drainage or seepage, appliance drainage, and underslab drain tile systems shall be directly connected to a sump (pump) and discharged at an elevation at least three feet above the RFD.

Statutory Authority: *MS s 104.05*

Published Electronically: *January 30, 2024*