

1346.0504 SECTION 504 CLOTHES DRYER EXHAUST.

IMC Section 504.1 is amended to read as follows:

504.1 Installation. Clothes dryers shall be exhausted in accordance with the manufacturer's instructions. Dryer exhaust systems shall be independent of all other systems and shall convey the moisture and any products of combustion to the outside of the building.

Exception: This section shall not apply to listed and labeled condensing (ductless) clothes dryers. The room where a listed and labeled condensing (ductless) clothes dryer is installed shall be provided with an exhaust ventilation system of 70 cfm or greater and shall have a floor drain or other approved plumbing fixture or disposal area for condensate.

Statutory Authority: *MS s 326B.101; 326B.106; 326B.13*

History: *34 SR 537*

Published Electronically: *October 23, 2009*