

**1346.0507 SECTION 507 COMMERCIAL KITCHEN HOODS.**

Subpart 1. **Section 507.1.** IMC section 507.1 and all subsections are deleted in their entirety and replaced with the following:

**507.1 General.** Commercial kitchen exhaust hoods shall comply with the requirements of this section.

**507.1.1 Type I hood construction and installation.** Type I hood construction and installation shall comply with NFPA 96 and ASHRAE 154.

**507.1.2 Type II hood construction and installation.** Type II hood construction and installation shall comply with this code and ASHRAE 154.

**507.1.2.1 Type II hood materials.** Type II hood materials shall be constructed of stainless steel not less than 0.024 inch (0.61 mm) (No. 24 Gage) in thickness, copper sheets weighing not less than 24 ounces per square foot (7.3 kg/m<sup>2</sup>), or of other approved material and gage.

Subp. 2. **Sections 507.2 to 507.6.1.** IMC sections 507.2 to 507.6.1 are deleted in their entirety and replaced with NFPA 96 and ASHRAE 154.

Subp. 3. [Repealed, 34 SR 537]

Subp. 4. [Repealed, 39 SR 690]

Subp. 5. [Repealed, 34 SR 537]

Subp. 6. [Repealed, 44 SR 1085]

Subp. 7. [Repealed, 44 SR 1085]

Subp. 8. [Repealed, 44 SR 1085]

Subp. 9. [Repealed, 44 SR 1085]

Subp. 10. [Repealed, 44 SR 1085]

Subp. 11. [Repealed, 34 SR 537]

Subp. 12. [Repealed, 44 SR 1085]

Subp. 13. [Repealed, 34 SR 537]

**Statutory Authority:** *MS s 16B.59; 16B.61; 16B.64; 326B.02; 326B.101; 326B.106; 326B.13*

**History:** *29 SR 299; L 2007 c 140 art 4 s 61; art 13 s 4; 34 SR 537; 39 SR 690; 44 SR 1085*

**Published Electronically:** *April 22, 2020*