

**1346.1206 SECTION 1206 PIPING INSTALLATION.**

Subpart 1. **Section 1206.1.1.** IMC Section 1206.1.1 is amended to read as follows:

**1206.1.1 Prohibited tee applications.** Fluid in the supply side of a hydronic system shall not enter a tee fitting through the branch opening. Fluid from two returns shall not enter on the run of the same tee.

Subp. 2. **Section 1206.12.** IMC Section 1206 is amended by adding a new subsection to the end of the section to read as follows:

**1206.12 Mixing of radiation.** Mixing radiation with different rates of heat transfer shall not be permitted in the same heating zone.

**Exception:** Engineered design installations.

Subp. 3. **Section 1206.13.** IMC Section 1206 is amended by adding a new subsection to the end of the section to read as follows:

**1206.13 Draining and venting.** Hydronic pipes shall be installed so that the pipes can be drained and so that air can be completely removed from the system during filling.

**Statutory Authority:** *MS s 326B.101; 326B.106; 326B.13*

**History:** *34 SR 537*

**Published Electronically:** *October 23, 2009*