

1513.0470 REINSTALLATION OF CONTAINERS.

Containers of a size to require a field fabrication must, when moved and reinstalled, be reconstructed and reinspected in complete accordance with the original requirements under which they were constructed. The containers must be subjected to a pressure retest, and if rerating is necessary, it must be done in accordance with the applicable pressure of the original requirements.

Statutory Authority: *MS s 18C.121*

History: *21 SR 277*

Published Electronically: *September 10, 2007*