

**2911.7300 FIRE INSPECTION.**

Subpart 1. **Annual inspection.** Each facility shall by policy require that a fire inspection of the facility must be conducted in accordance with the applicable fire code on an annual basis by a state fire marshal or local fire official.

Subp. 2. **Documentation.** Documentation of the inspection and any orders resulting from the inspection must be maintained and available to the DOC.

Subp. 3. **Sanction.** Failure to comply with the applicable fire code and safety requirements will result in the commissioner's denial of approval to continue facility operation.

Subp. 4. **Weekly inspection.** There shall be an applicable fire code and safety inspection of the facility at least weekly by a designated staff member.

Subp. 5. **Fire alarm requirements.** There shall be a fire alarm and automatic detection system required, as approved by the authority having jurisdiction, or a plan for addressing these or other deficiencies within a reasonable time. The authority may approve any variances, exceptions, or equivalencies.

**Statutory Authority:** *MS s 241.021*

**History:** *23 SR 1834; 38 SR 523*

**Published Electronically:** *December 20, 2013*