

**4625.1300 WATER SUPPLY.**

A safe adequate supply of water shall be provided. The water supply system shall be located, constructed, and operated in accordance with the rules of the commissioner. After September 30, 1980, the temperature of hot water which is provided in any public area or guest room, including but not limited to lavatories, bathtubs, or showers, shall not exceed 130 degrees Fahrenheit (approximately 55 degrees Celsius).

**Statutory Authority:** *MS s 144.08; 144.12; 157.01 to 157.14; 327.10 to 327.67*

**Published Electronically:** *January 21, 2000*