

4626.1055 5-202.13 BACKFLOW PREVENTION; AIR GAP.*

An air gap between the water supply inlet and the flood level rim of the plumbing fixture, equipment, or nonfood equipment shall be at least twice the diameter of the water supply inlet and shall not be less than 25 millimeters (one inch).

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011*

History: *23 SR 519*

Published Electronically: *October 11, 2007*