

**4626.1085 BACKFLOW PREVENTION DEVICE; WHEN REQUIRED. 5-203.14**

A. A plumbing system must be installed to preclude backflow of a solid, liquid, or gas contaminant into the water supply system at each point of use at the food establishment according to chapter 4714.<sup>p1</sup>

B. A backflow prevention device must be located so that it may be serviced and maintained.

**Statutory Authority:** *MS s 31.101; 31.11; 144.05; 144.07; 144.08; 144.12; 157.011*

**History:** *23 SR 519; 43 SR 295*

**Published Electronically:** *January 2, 2019*