4626.1100 5-204.12 BACKFLOW PREVENTION DEVICE; LOCATION.

A backflow prevention device shall be located so that it may be serviced and maintained.

Statutory Authority: MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011

History: 23 SR 519

Published Electronically: October 11, 2007