

4626.1120 5-205.13 SCHEDULING INSPECTION AND SERVICE FOR WATER TREATMENT DEVICE.

A. A water treatment device, other than a water softener, shall be scheduled for inspection and service according to the manufacturer's instructions and as necessary to prevent device failure based on local water conditions.

B. A backflow preventer shall be inspected, tested, and maintained according to chapter 4714.

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011*

History: *23 SR 519; 40 SR 71*

Published Electronically: *April 1, 2016*