

4626.1160 5-304.11 SYSTEM FLUSHING AND DISINFECTION.*

A water tank, pump, and hose shall be flushed and sanitized before being placed in service after construction, repair, modification, and periods of nonuse.

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011*

History: *23 SR 519*

Published Electronically: *October 11, 2007*