

**4626.1345 FLOOR AND WALL JUNCTURES; COVERED AND ENCLOSED OR SEALED.
6-201.13**

A. In food establishments in which cleaning methods other than water flushing are used for cleaning floors, the floor and wall junctures must be covered and closed to no larger than 1/32 inch (1 millimeter).

B. The floors in food establishments in which water flushing cleaning methods are used must be provided with drains and graded to drain, and the floor and wall junctures must be covered and sealed.

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.07; 144.08; 144.12; 157.011*

History: *23 SR 519; 43 SR 295*

Published Electronically: *January 2, 2019*