

4630.1600 FUEL OIL SUPPLY SYSTEMS.

All piping from outside fuel storage tanks or cylinders to mobile homes or recreational camping vehicles shall be permanently installed and securely fastened in place. All fuel oil storage tanks or cylinders shall be securely fastened in place and shall not be located inside or beneath any mobile home or recreational camping vehicle or less than five feet from any mobile home or recreational camping vehicle exit. All fuel oil containers shall be mounted upon a stand or rack constructed of a noncombustible material.

Statutory Authority: *MS s 327.10 to 327.28*

Published Electronically: *February 8, 2005*