

**4645.2800 HEATING, PIPING, VENTILATION, AND AIR-CONDITIONING.**

The heating system, piping, boilers, ventilation, and air-conditioning shall be furnished and installed to meet the requirements as set forth herein and the requirements of Part II of Standard No. 56, issued in May, 1954, entitled Recommended Safe Practice for Hospital Operating Rooms by the National Fire Protection Association, 60 Batterymarch Street, Boston, Massachusetts, which part of said standard is hereby adopted by the commissioner of health with the same force and effect as if the same were fully set forth in and written as part of this part. It is recommended that ventilating systems be designed for air cooling or for the future addition of air cooling.

**Statutory Authority:** *MS s 144.55; 144.56*

**History:** *L 1977 c 305 s 39*

**Published Electronically:** *August 7, 2013*