

**4658.4415 ELEVATORS; NEW CONSTRUCTION.**

Subpart 1. **Elevators.** Shaft enclosures and elevator installations must be provided in accordance with part 4658.3500, subpart 5. Elevators must be provided in all facilities where residents occupy or use more than the entrance or first floor level.

Subp. 2. **Elevator cab size.** At least one elevator must have an inside cab dimension of at least five feet wide and seven feet deep. The car doors must have a clear opening of at least three feet, eight inches.

**Statutory Authority:** *MS s 144A.04; 144A.08*

**History:** *21 SR 196*

**Published Electronically:** *October 11, 2007*