

4658.4530 HEIGHT OF REGISTERS; NEW CONSTRUCTION.

Wall openings for air supply or return must be located at least four inches above the floor.

Statutory Authority: *MS s 144A.04; 144A.08*

History: *21 SR 196*

Published Electronically: *October 11, 2007*