

**4658.4605 CORRIDOR RECEPTACLES; NEW CONSTRUCTION.**

Single receptacles on a separate circuit for equipment such as floor cleaning machines must be installed approximately 50 feet apart in all corridors and within 25 feet of ends of corridors.

**Statutory Authority:** *MS s 144A.04; 144A.08*

**History:** *21 SR 196*

**Published Electronically:** *October 11, 2007*