

4658.4610 SWITCHES AND RECEPTACLES; NEW CONSTRUCTION.

Switches must be placed between 42 inches and 48 inches above the floor. Convenience outlets for electrical appliances must be located to avoid danger in wet areas.

Statutory Authority: *MS s 144A.04; 144A.08*

History: *21 SR 196*

Published Electronically: *October 11, 2007*