

4660.8330 HEIGHT OF REGISTERS, NEW CONSTRUCTION.

Registers for air supply or return shall be located not less than four inches above the floor.

Statutory Authority: *MS s 144.56; 144A.02 to 144A.08*

Published Electronically: *October 11, 2007*