

4660.8370 MECHANICAL ROOMS, NEW CONSTRUCTION.

Mechanical rooms below grade with equipment utilizing liquefied petroleum gas shall be provided with continuous mechanical ventilation providing a pressure which is equal or greater than atmospheric.

Statutory Authority: *MS s 144.56; 144A.02 to 144A.08*

Published Electronically: *October 11, 2007*