

4660.8430 CORRIDOR RECEPTACLES, NEW CONSTRUCTION.

Single receptacles on a separate circuit for equipment such as floor cleaning machines shall be installed approximately 50 feet apart in all corridors and within 25 feet of ends of corridors.

Statutory Authority: *MS s 144.56; 144A.02 to 144A.08*

Published Electronically: *October 11, 2007*