

4660.9940 VENTILATION PRESSURE RELATIONSHIPS AND VENTILATION FOR CERTAIN AREAS.

Subpart 1. **Applicability.** Subpart 2 applies to boarding care homes only.

Subp. 2. **Table.**

Area Designation	Pressure ¹ Relationship to Adjacent Areas	All Supply Air From Outdoors	Air Changes of Outdoor Air per Hour	Minimum Total Air Changes per Hour	All Exhaust Directly to Outdoors	Recirculated Within Room
Resident Bedroom ²	0	—	2	2	—	—
Dayroom, Activity Area	0	—	2	4	—	—
Resident Corridor	0	—	2	4	—	—
Dining Room	—	—	2	6	—	—
Toilet Room	—	—	—	10	Yes	No
Bathing Area	—	—	—	10	Yes	No
Barber and Beauty Room	—	—	—	10	Yes	No
Janitor's Closet	—	—	—	10	Yes	No
Trash Collection, Garbage Can Washing	—	—	—	10	Yes	No
Food Preparation, Nourishment	0	—	2	10	Yes	No
Dishwashing, Food Cart	—	—	—	10	Yes	No
Cleaning Area	—	—	—	10	Yes	No
Dietary Storage	0	—	—	2	—	No
Laundry Processing Room	0	—	2	10	Yes	No
Soiled Linen Collection Room	—	—	—	10	Yes	No
Clean Linen Storage	+	—	2	2	—	—

Symbols:

Air Pressure Relationships: + = Positive — = Negative

Air Changes, Supply, Exhaust: — = Optional

¹ Areas with equal or positive pressure relationships to adjacent areas shall be provided with tempered make-up air.

² For residents' bedrooms, operable windows may provide adequate ventilation.

Statutory Authority: *MS s 144A.02 to 144A.08*

Published Electronically: *October 11, 2007*