

4714.0407 LAVATORIES.

Subpart 1. **UPC section 407.3.** UPC section 407.3 is amended as follows:

407.3 Limitation of Hot Water Temperature for Public Lavatories. Hot water delivered from public-use lavatories shall be limited to a maximum temperature of 110 degrees Fahrenheit (43 degrees Celsius). The maximum temperature shall be regulated by one of the following means:

- (1) a limiting device conforming to ASSE 1070/ASME A112.1070 /CSA B125.70; or
- (2) a water heater conforming to ASSE 1084.

Subp. 2. UPC section 407.4 is deleted in its entirety.

Statutory Authority: *MS s 326B.43*

History: *45 SR 1007*

Published Electronically: *September 27, 2021*