

4714.0416 EMERGENCY EYEWASH AND SHOWER EQUIPMENT.

UPC section 416.2 is amended to read as follows:

416.2 Water Supply. Emergency eyewash and shower equipment shall not be limited in the water supply flow rates. Where hot and cold water is supplied to an emergency shower or eyewash station, the temperature of the water supply shall be controlled by a temperature actuated mixing valve complying with ASSE 1071. Where water is supplied directly to an emergency shower or eyewash station from a water heater, the water heater shall comply with ASSE 1085. Flow rate, discharge pattern, and temperature of flushing fluids shall be provided in accordance with ISEA Z358.1 based on the hazardous material.

Statutory Authority: *MS s 326B.43*

History: *45 SR 1007*

Published Electronically: *September 27, 2021*