

**4714.0420 SINKS.**

UPC section 420.4 is amended to read as follows:

**420.4 Waste Outlet.** Kitchen and laundry sinks shall have a waste outlet and fixture tailpiece not less than 1-1/2 inches (40 mm) in diameter, except commercial pot and scullery sinks shall be provided with waste outlets not less than 2 inches (50 mm) in diameter. Service sinks shall have a waste outlet and fixture tailpiece not less than 2 inches (50 mm) in diameter. Fixture tailpieces shall be constructed from the materials specified in section 701.2 for drainage piping, provided, however, that the connections where exposed or accessible shall be permitted to be of seamless drawn brass not less than No. 20 B & S Gauge (0.032 inches) (0.81 mm). Waste outlets shall be provided with an approved strainer.

**Statutory Authority:** *MS s 326B.43; 326B.435*

**History:** *40 SR 71; 45 SR 1007*

**Published Electronically:** *September 27, 2021*