

**4714.0715 BUILDING SEWER MATERIALS.**

UPC section 715.3 is amended to read as follows:

**715.3 Existing Sewers.** Replacement of existing building sewer and building storm sewers using cured-in-place pipe lining trenchless methodology and materials shall be installed in accordance with ASTM F 1216. Replacement using cured-in-place pipe liners shall not be used on collapsed piping or when the existing piping is compromised to a point where the installation of the liners will not eliminate hazardous or insanitary conditions.

**Statutory Authority:** *MS s 326B.43; 326B.435*

**History:** *40 SR 71*

**Published Electronically:** *January 25, 2016*