

**4714.0717 SIZE OF BUILDING SEWERS.**

UPC section 717, Table 717.1, is amended to read as follows:

**TABLE 717.1**

**Maximum/Minimum Fixture Unit Loading on Building Sewer Piping**

**SLOPE (inches per foot)**

<b>Size of Pipe (inches)</b>	<b>1/16</b>	<b>1/8</b>	<b>1/4</b>
6 and smaller	(As specified in Table 703.2/No minimum loading)		
8	1950/1500	2800/625	3900/275
10	3400/1600	4900/675	6800/300
12	5600/1700	8000/725	11 200/325

For SI units: 1 inch = 25 mm, 1 inch per foot = 83.3 mm/m

**Statutory Authority:** *MS s 326B.43; 326B.435*

**History:** *40 SR 71*

**Published Electronically:** *January 25, 2016*