

4714.0717 SIZE OF BUILDING SEWERS.

UPC section 717, Table 717.1, is amended to read as follows:

TABLE 717.1**Maximum/Minimum Fixture Unit Loading on Building Sewer Piping**

Size of Pipe (inches)	SLOPE (inches per foot)		
	1/16	1/8	1/4
6 and smaller	(As specified in Table 703.2/No minimum loading)		
8*	1950/1500	2800/625	3900/275
10*	3400/1600	4900/675	6800/300
12*	5600/1700	8000/725	11 200/325

*Loadings less than the listed minimums must be approved by the Authority Having Jurisdiction.

For SI units: 1 inch = 25 mm, 1 inch per foot = 83.3 mm/m

Statutory Authority: *MS s 326B.43; 326B.435*

History: *40 SR 71; 45 SR 1007*

Published Electronically: *September 27, 2021*