

4714.0719 CLEANOUTS.

UPC section 719.6 is amended to read as follows:

719.6 Manholes. Approved manholes shall be permitted to be installed in lieu of cleanouts, where first approved by the Authority Having Jurisdiction. The maximum distance between manholes shall not exceed 300 feet (91,400 mm). Connections to manhole and similar structures must be provided as follows:

1. The inlet and outlet connections shall be made by the use of a flexible compression joint not less than 12 inches (305 mm) and not exceeding 3 feet (914 mm) from the manhole. No flexible compression joints shall be embedded in the manhole base.
2. Approved resilient rubber joints must be used to make watertight connections to manholes, catch basins, and other structures.

Statutory Authority: *MS s 326B.43*

History: *45 SR 1007*

Published Electronically: *September 27, 2021*