

4714.0814 CONDENSATE WASTES AND CONTROL.

Subpart 1. **Section 814.1.** UPC section 814.1 is amended to read as follows:

814.1 Condensate Disposal. Where discharged into the drainage system, equipment shall drain by means of an indirect waste pipe.

Subp. 2. **Table 814.3.** UPC Table 814.3 is deleted.

Subp. 3. **Section 814.3.** UPC section 814.3 is deleted in its entirety.

Subp. 4. **Section 814.5.** UPC section 814.5 is amended to read as follows:

814.5 Point of Discharge. Air-conditioning condensate waste pipes shall connect indirectly to the interior drainage system through an air gap or air break to: (1) properly trapped and vented receptors; (2) the tailpiece of an approved plumbing fixture; or (3) an exterior place of disposal approved by the Minnesota Pollution Control Agency.

Condensate waste shall not drain over a public way or in areas causing a nuisance.

Statutory Authority: *MS s 326B.43; 326B.435*

History: *40 SR 71; 45 SR 1007*

Published Electronically: *September 27, 2021*