

4714.1002 TRAPS PROTECTED BY VENT PIPES.

UPC section 1002.2 is amended to read as follows:

1002.2 Fixture Traps. Each fixture trap shall have a protecting vent located so that the developed length of the trap arm from the trap weir to the inner edge of the vent shall be within the distance given in Table 1002.2 but in no case less than two times the diameter of the trap arm.

Exception: Emergency floor drains, tell tale floor drains, and floor drains not used as waste receptors installed within 25 feet of a vented branch or main.

Statutory Authority: *MS s 326B.43*

History: *45 SR 1007*

Published Electronically: *September 27, 2021*