

4717.3550 DRESSING ROOMS.

When dressing rooms are provided for both sexes, they must be separated by a tight partition and be designated for men or women.

- A. The entrances must be screened to break line of sight.
- B. Floors and wet paths between showers and the pool must have a smooth, nonslip surface, impervious to moisture, and sloped to a drain.
- C. The junctions between walls and floors must be coved or provided with a sealed, easily cleaned joint.
- D. Walls and partitions must be of smooth, impervious material, free from cracks or open joints.
- E. Lockers must be set either on solid masonry bases four inches high or on legs with the bottom of the locker at least ten inches above the floor. Lockers must be vented.

Statutory Authority: *MS s 144.05; 144.12; 144.123; 145A.02; 157.01*

History: *19 SR 1419; 19 SR 1637*

Published Electronically: *May 11, 2009*