

4720.3925 SHORE WELLS.

Shore well structures must:

- A. have motors and electrical controls located above grade and flood level;
 - B. be accessible for operation and service;
 - C. be designed to prevent flotation;
 - D. be equipped with removable or traveling screens before the pump suction well;
 - E. provide chlorination or other chemical addition facilities for raw water transmission mains;
 - F. have the intake valved with provisions for backflushing and testing for leaks;
- and
- G. have provisions for controlling surges.

Statutory Authority: *MS s 144.383*

History: *15 SR 1842*

Published Electronically: *October 27, 2003*